



VIPA System 300S



SM-AIO | Manual

HB140E_SM-AIO | Rev. 12/21

May 2012

Copyright © VIPA GmbH. All Rights Reserved.

This document contains proprietary information of VIPA and is not to be disclosed or used except in accordance with applicable agreements.

This material is protected by the copyright laws. It may not be reproduced, distributed, or altered in any fashion by any entity (either internal or external to VIPA), except in accordance with applicable agreements, contracts or licensing, without the express written consent of VIPA and the business management owner of the material.

For permission to reproduce or distribute, please contact:
VIPA, Gesellschaft für Visualisierung und Prozessautomatisierung mbH
Ohmstraße 4, D-91074 Herzogenaurach, Germany
Tel.: +49 (91 32) 744 -0
Fax.: +49 9132 744 1864
EMail: info@vipa.de
<http://www.vipa.de>

Note

Every effort has been made to ensure that the information contained in this document was complete and accurate at the time of publishing. Nevertheless, the authors retain the right to modify the information. This customer document describes all the hardware units and functions known at the present time. Descriptions may be included for units which are not present at the customer site. The exact scope of delivery is described in the respective purchase contract.

CE Conformity

Hereby, VIPA GmbH declares that the products and systems are in compliance with the essential requirements and other relevant provisions of the following directives:

- 2004/108/EC Electromagnetic Compatibility Directive
- 2006/95/EC Low Voltage Directive

Conformity is indicated by the CE marking affixed to the product.

Conformity Information

For more information regarding CE marking and Declaration of Conformity (DoC), please contact your local VIPA customer service organization.

Trademarks

VIPA, SLIO, System 100V, System 200V, System 300V, System 300S, System 400V, System 500S and Commander Compact are registered trademarks of VIPA Gesellschaft für Visualisierung und Prozessautomatisierung mbH.

SPEED7 is a registered trademark of profichip GmbH.

SIMATIC, STEP, SINEC, S7-300 and S7-400 are registered trademarks of Siemens AG.

Microsoft und Windows are registered trademarks of Microsoft Inc., USA.

Portable Document Format (PDF) and Postscript are registered trademarks of Adobe Systems, Inc.

All other trademarks, logos and service or product marks specified herein are owned by their respective companies.

Information product support

Contact your local VIPA Customer Service Organization representative if you wish to report errors or questions regarding the contents of this document. If you are unable to locate a customer service center, contact VIPA as follows:

VIPA GmbH, Ohmstraße 4, 91074 Herzogenaurach, Germany

Telefax: +49 9132 744 1204
EMail: documentation@vipa.de

Technical support

Contact your local VIPA Customer Service Organization representative if you encounter problems with the product or have questions regarding the product. If you are unable to locate a customer service center, contact VIPA as follows:

VIPA GmbH, Ohmstraße 4, 91074 Herzogenaurach, Germany

Telephone: +49 9132 744 1150 (Hotline)
EMail: support@vipa.de

Contents

About this manual	1
Safety information	2
Chapter 1 Assembly and installation guidelines.....	1-1
Safety Information for Users.....	1-2
Overview	1-3
Installation dimensions	1-4
Assembly SPEED-Bus	1-5
Assembly standard bus	1-9
Cabling.....	1-11
Installation guidelines	1-14
General data	1-17
Chapter 2 Analog Input Modules.....	2-1
Principles.....	2-2
Parameterization - Basics.....	2-3
331-1KF01 - AI 8x13Bit	2-6
331-1KF01 - AI 8x13Bit - Parameterization	2-9
331-1KF01 - AI 8x13Bit - Technical Data	2-13
331-7Kx01 - AI 8(2)x12Bit	2-16
331-7Kx01 - AI 8(2)x12Bit - Parameterization	2-23
331-7Kx01 - AI 8(2)x12Bit - Diagnostics.....	2-28
331-7Kx01 - AI 8x12Bit - Technical Data.....	2-34
Chapter 3 Analog Output Modules.....	3-1
General	3-2
Connecting loads and actuators	3-3
Analog value representation.....	3-4
Parameterization - Basics.....	3-5
Diagnostics.....	3-8
332-5HB01 - AO 2/4x12Bit U/I 2-channel.....	3-12
332-5HD01 - AO 2/4x12Bit U/I 4-channel.....	3-16
332-5HD50 - AO 4x12Bit I for manual operation	3-20
332-5HD60 - AO 4x12Bit U for manual operation.....	3-25
Chapter 4 Analog In/Output Modules.....	4-1
General	4-2
Analog value representation.....	4-3
Parameterization	4-5
334-0KE00 - AI 4/AO 2x12Bit.....	4-7
Chapter 5 Analog I/O modules FAST - SPEED-Bus	5-1
General	5-2
Analog value representation.....	5-3
Operating modes.....	5-4
Addressing at SPEED-Bus	5-5
Project engineering	5-6
Parameterization	5-10
SFC 193 - Oscilloscope-/FIFO function	5-15
Example for the oscilloscope function	5-18
Example for the FIFO function	5-21
Diagnostics.....	5-25
331-7AF70 - AI 8x16Bit I	5-28
331-7BF70 - AI 8x16Bit U.....	5-32

About this manual

This manual describes the VIPA System 300S analog signal modules and the analog signal modules FAST for SPEED-Bus.

Here you may find besides of a product overview a detailed description of the single modules. You'll receive information about the connection and the deployment of the System 300S SM modules.

Overview

Chapter 1: Installation and assembly guide lines

In this chapter you will find all information, required for the installation and the cabling of a process control with the components of the System 300S.

Chapter 2: Analog in-/output modules

This chapter contains a description of the structure and the operation of the VIPA analog input modules.

Chapter 3: Analog in-/output modules

This chapter contains a description of the structure and the operation of the VIPA analog output modules.




Chapter 4: Analog in-/output modules

This chapter contains a description of the structure and the operation of the VIPA analog in/output modules.

Chapter 5: Analog modules FAST - SPEED-Bus

Contents of this chapter are the structure and the functionality of the fast analog modules for VIPA SPEED-Bus.

The modules may only be used at SPEED-Bus slots at the left side of the CPU.

Objective and contents	This manual describes the analog signal modules (SM) that can be used with the System 300S. It contains a description of the construction, project engineering and technical data.
Target audience	The manual is targeted at users who have a background in automation technology.
Structure of the manual	The manual consists of chapters. Every chapter provides a self-contained description of a specific topic.
Guide to the document	The following guides are available in the manual: <ul style="list-style-type: none">• an overall table of contents at the beginning of the manual• an overview of the topics for every chapter
Availability	The manual is available in: <ul style="list-style-type: none">• printed form, on paper• in electronic form as PDF-file (Adobe Acrobat Reader)
Icons Headings	Important passages in the text are highlighted by following icons and headings:
	Danger! Immediate or likely danger. Personal injury is possible.
	Attention! Damages to property is likely if these warnings are not heeded.
	Note! Supplementary information and useful tips.

Safety information

Applications conforming with specifications

The modules of the System 300S are constructed and produced for:

- all VIPA System 300S components
- communication and process control
- general control and automation applications
- industrial applications
- operation within the environmental conditions specified in the technical data
- installation into a cubicle



Danger!

This device is not certified for applications in

- in explosive environments (EX-zone)

Documentation

The manual must be available to all personnel in the

- project design department
- installation department
- commissioning
- operation



The following conditions must be met before using or commissioning the components described in this manual:

- Modification to the process control system should only be carried out when the system has been disconnected from power!
- Installation and modifications only by properly trained personnel
- The national rules and regulations of the respective country must be satisfied (installation, safety, EMC ...)

Disposal

National rules and regulations apply to the disposal of the unit!

Chapter 1 Assembly and installation guidelines

Overview In this chapter you will find all information, required for the installation and the cabling of a process control with the components of the System 300S.

Content	Topic	Page
	Chapter 1 Assembly and installation guidelines	1-1
	Safety Information for Users	1-2
	Overview	1-3
	Installation dimensions	1-4
	Assembly SPEED-Bus	1-5
	Assembly standard bus	1-9
	Cabling	1-11
	Installation guidelines	1-14
	General data	1-17

Safety Information for Users

Handling of electrostatic sensitive modules

VIPA modules make use of highly integrated components in MOS-Technology. These components are extremely sensitive to over-voltages that can occur during electrostatic discharges.

The following symbol is attached to modules that can be destroyed by electrostatic discharges.



The Symbol is located on the module, the module rack or on packing material and it indicates the presence of electrostatic sensitive equipment.

It is possible that electrostatic sensitive equipment is destroyed by energies and voltages that are far less than the human threshold of perception. These voltages can occur where persons do not discharge themselves before handling electrostatic sensitive modules and they can damage components thereby, causing the module to become inoperable or unusable.

Modules that have been damaged by electrostatic discharges can fail after a temperature change, mechanical shock or changes in the electrical load.

Only the consequent implementation of protection devices and meticulous attention to the applicable rules and regulations for handling the respective equipment can prevent failures of electrostatic sensitive modules.

Shipping of modules

Modules must be shipped in the original packing material.

Measurements and alterations on electrostatic sensitive modules

When you are conducting measurements on electrostatic sensitive modules you should take the following precautions:

- Floating instruments must be discharged before use.
- Instruments must be grounded.

Modifying electrostatic sensitive modules you should only use soldering irons with grounded tips.



Attention!


Personnel and instruments should be grounded when working on electrostatic sensitive modules.

Overview

General

While the standard peripheral modules are plugged-in at the right side of the CPU, the SPEED-Bus peripheral modules are connected via a SPEED-Bus bus connector at the left side of the CPU.

VIPA delivers profile rails with integrated SPEED-Bus for 2, 6 or 10 SPEED-Bus peripheral modules with different lengths.



Serial Standard bus

The single modules are directly installed on a profile rail and connected via the backplane bus coupler. Before installing the modules you have to clip the backplane bus coupler to the module from the backside. The backplane bus couplers are included in the delivery of the peripheral modules.

Parallel SPEED-Bus


With SPEED-Bus the bus connection happens via a SPEED-Bus rail integrated in the profile rail at the left side of the CPU. Due to the parallel SPEED-Bus not all slots must be occupied in sequence.

SLOT 1 for additional power supply

At slot (SLOT 1 DCDC) you may plug either a SPEED-Bus module or an additional power supply.

Assembly possibilities

You may assemble the System 300S horizontally, vertically or lying.




Please regard the allowed environment temperatures:

- horizontal assembly: from 0 to 60°C
- vertical assembly: from 0 to 40°C
- lying assembly: from 0 to 40°C


Installation dimensions

Dimensions 1tier width (WxHxD) in mm: 40 x 125 x 120
Basic enclosure

Dimensions



Installation dimensions



Assembly SPEED-Bus

Pre-manufactured SPEED-Bus profile rail


For the deployment of SPEED-Bus modules, a pre-manufactured SPEED-Bus rail is required. This is available mounted on a profile rail with 2, 6 or 10 extension plug-in locations.



Dimensions


Order number	Number of modules SPEED-Bus/Standard bus	A	B	C	D	E
VIPA 391-1AF10	2/6	530	100	268	510	10
VIPA 391-1AF30	6/2	530	100	105	510	10
VIPA 391-1AF50	10/0	530	20	20	510	10
VIPA 391-1AJ10	2/15	830	22	645	800	15
VIPA 391-1AJ30	6/11	830	22	480	800	15
VIPA 391-1AJ50	10/7	830	22	320	800	15

Measures in mm




Installation of the profile rail


- Bolt the profile rail with the background (screw size: M6), so that you still have minimum 65mm space above and 40mm below the profile rail.
- Please look for a low-impedance connection between profile rail and background



- Connect the profile rail with the protected earth conductor. The minimum cross-section of the cable to the protected earth conductor has to be 10mm².



**Installation
SPEED-Bus
module**




- Dismantle the according protection flaps of the SPEED-Bus plug-in locations with a screw driver (open and pull down).
For the SPEED-Bus is a parallel bus, not all SPEED-Bus plug-in locations must be used in series. Leave the protection flap installed at an unused SPEED-Bus plug-in location.

- At deployment of a DC 24V power supply, install it at the shown position at the profile rail at the left side of the SPEED-Bus and push it to the left to the isolation bolt of the profile rail.
- Fix the power supply by screwing.


- To connect the SPEED-Bus modules, plug it between the triangular positioning helps to a plug-in location marked with "SLOT ..." and pull it down.
- On "SLOT DCDC" you can only plug-in SPEED-Bus modules. The deployment of the additional power supply (Co power supply) provided for it is not permitted!
- Fix the modules by screwing.

**Installation CPU
without Standard-
Bus-Modules**




- To deploy the SPEED7-CPU exclusively at the SPEED-Bus, plug it between the triangular positioning helps to the plug-in location marked with "CPU SPEED7" and pull it down.
- Fix the CPU by screwing.

Installation CPU
with Standard-Bus-
Modules



- If also standard modules shall be plugged, take a bus coupler and click it at the CPU from behind like shown in the picture.
- Plug the CPU between the triangular positioning helps to the plug-in location marked with "CPU SPEED7" and pull it down.
- Fix the CPU by screwing.

Installation
Standard-Bus-
Modules



- Repeat this procedure with the peripheral modules, by clicking a backplane bus coupler, stick the module right from the modules you've already fixed, click it downwards and connect it with the backplane bus coupler of the last module and bolt it.



Danger!

- Before installing or overhauling the System 300V, the power supplies must be disconnected from voltage (pull the plug or remove the fuse)!
- Installation and modifications only by properly trained personnel!

Assembly standard bus

General

The single modules are directly installed on a profile rail and connected via the backplane bus connector. Before installing the modules you have to clip the backplane bus connector to the module from the backside.


The backplane bus connector is delivered together with the peripheral modules.

Profile rail

Order number	A	B	C
VIPA 390-1AB60	160	140	10
VIPA 390-1AE80	482	466	8.3
VIPA 390-1AF30	530	500	15
VIPA 390-1AJ30	830	800	15
VIPA 390-9BC00*	2000	Drillings only left	15


* Unit pack: 10 pieces

Measures in mm




Bus connector

For the communication between the modules the System 300S uses a backplane bus connector. Backplane bus connectors are included in the delivering of the peripheral modules and are clipped at the module from the backside before installing it to the profile rail.



Assembly possibilities


waagrechtlicher Aufbau



senkrechter Aufbau




liegender Aufbau



Please regard the allowed environment temperatures:

- horizontal assembly: from 0 to 60°C
- vertical assembly: from 0 to 40°C
- lying assembly: from 0 to 40°C

Approach



If you do not deploy SPEED-Bus modules, the assembly happens with the following approach:

- Bolt the profile rail with the background (screw size: M6), so that you still have minimum 65mm space above and 40mm below the profile rail.
- If the background is a grounded metal or device plate, please look for a low-impedance connection between profile rail and background.
- Connect the profile rail with the protected earth conductor. For this purpose there is a bolt with M6-thread.
- The minimum cross-section of the cable to the protected earth conductor has to be 10mm².
- Stick the power supply to the profile rail and pull it to the left side to the grounding bolt of the profile rail.
- Fix the power supply by screwing.
- Take a backplane bus connector and click it at the CPU from the backside like shown in the picture.
- Stick the CPU to the profile rail right from the power supply and pull it to the power supply.
- Click the CPU downwards and bolt it like shown.
- Repeat this procedure with the peripheral modules, by clicking a backplane bus connector, stick the module right from the modules you've already fixed, click it downwards and connect it with the backplane bus connector of the last module and bolt it.



Danger!

- The power supplies must be released before installation and repair tasks, i.e. before handling with the power supply or with the cabling you must disconnect current/voltage (pull plug, at fixed connection switch off the concerning fuse)!
- Installation and modifications only by properly trained personnel!

Cabling

Overview

The CPUs are exclusively delivered with CageClamp contacts. The connection of the I/O periphery happens by 20pole front screw connection.




Danger!

- The power supplies must be released before installation and repair tasks, i.e. before handling with the power supply or with the cabling you must disconnect current/voltage (pull plug, at fixed connection switch off the concerning fuse)!
- Installation and modifications only by properly trained personnel!


CageClamp technology (green)

For the cabling of power supply of a CPU, a green plug with CageClamp technology is deployed.


The connection clamp is realized as plug that may be clipped off carefully if it is still cabled.



Here wires with a cross-section of 0.08mm² to 2.5mm² may be connected. You can use flexible wires without end case as well as stiff wires.




- [1] Test point for 2mm test tip
- [2] Locking (orange) for screwdriver
- [3] Round opening for wires







The picture on the left side shows the cabling step by step from top view.

- For cabling you push the locking vertical to the inside with a suiting screwdriver and hold the screwdriver in this position.
- Insert the de-isolated wire into the round opening. You may use wires with a cross-section from 0.08mm² to 2.5mm².
- By removing the screwdriver the wire is connected safely with the plug connector via a spring.





Front connectors of the in-/output modules In the following the cabling of the two variants are shown:

<p>20pole screw connection VIPA 392-1AJ00</p>	<p>40pole screw connection VIPA 392-1AM00</p>
	
<p>Open the front flap of your I/O module.</p>	
<p>Bring the front connector in cabling position. For this you plug the front connector on the module until it locks. In this position the front connector juts out of the module and has no contact yet.</p>	
<p>De-isolate your wires. If needed, use core end cases.</p>	
<p>Thread the included cable binder into the front connector.</p>	
<p>If you want to lead out your cables from the bottom of the module, start with the cabling from bottom to top, res. from top to bottom, if the cables should be led out at the top.</p>	
<p>Bolt also the connection screws of not cabled screw clamps.</p>	
	<p>Put the included cable binder around the cable bundle and the front connector.</p> 
<p>Fix the cable binder for the cable bundle.</p>	

continued ...

... continue

20pole screw connection VIPA 392-1AJ00	40pole screw connection VIPA 392-1AM00
<p>Push the release key at the front connector on the upper side of the module and at the same time push the front connector into the module until it locks.</p>  <p>The diagram shows a hand pushing a release key (1) down on the top of the front connector (2) while the connector is being inserted into the module. Red arrows indicate the direction of the key and the connector.</p>	<p>Bolt the fixing screw of the front connector.</p>  <p>The diagram shows a screw being tightened onto the front connector (2) with a torque wrench (1). Red arrows indicate the tightening direction. Below the diagram, the torque specification is given as 0.4 ... 0.7 Nm.</p> <p>0.4 ... 0.7 Nm</p>
<p>Now the front connector is electrically connected with your module.</p>	
<p>Close the front flap.</p>	
<p>Fill out the labeling strip to mark the single channels and push the strip into the front flap.</p>	

Installation guidelines

General The installation guidelines contain information about the interference free deployment of System 300S systems. There is the description of the ways, interference may occur in your control, how you can make sure the electromagnetic digestibility (EMC), and how you manage the isolation.

What means EMC? Electromagnetic digestibility (EMC) means the ability of an electrical device, to function error free in an electromagnetic environment without being interferenced res. without interfering the environment.
All System 300S components are developed for the deployment in hard industrial environments and fulfill high demands on the EMC. Nevertheless you should project an EMC planning before installing the components and take conceivable interference causes into account.

Possible interference causes Electromagnetic interferences may interfere your control via different ways:

- Fields
- I/O signal conductors
- Bus system
- Current supply
- Protected earth conductor

Depending on the spreading medium (lead bound or lead free) and the distance to the interference cause, interferences to your control occur by means of different coupling mechanisms.

One differs:

- galvanic coupling
- capacitive coupling
- inductive coupling
- radiant coupling

Basic rules for EMC

In the most times it is enough to take care of some elementary rules to guarantee the EMC. Please regard the following basic rules when installing your PLC.

- Take care of a correct area-wide grounding of the inactive metal parts when installing your components.
 - Install a central connection between the ground and the protected earth conductor system.
 - Connect all inactive metal extensive and impedance-low.
 - Please try not to use aluminum parts. Aluminum is easily oxidizing and is therefore less suitable for grounding.
- When cabling, take care of the correct line routing.
 - Organize your cabling in line groups (high voltage, current supply, signal and data lines).
 - Always lay your high voltage lines and signal res. data lines in separate channels or bundles.
 - Route the signal and data lines as near as possible beside ground areas (e.g. suspension bars, metal rails, tin cabinet).
- Proof the correct fixing of the lead isolation.
 - Data lines must be laid isolated.
 - Analog lines must be laid isolated. When transmitting signals with small amplitudes the one sided laying of the isolation may be favorable.
 - Lay the line isolation extensively on an isolation/protected earth conductor rail directly after the cabinet entry and fix the isolation with cable clamps.
 - Make sure that the isolation/protected earth conductor rail is connected impedance-low with the cabinet.
 - Use metallic or metalized plug cases for isolated data lines.
- In special use cases you should appoint special EMC actions.
 - Wire all inductivities with erase links.
 - Please consider luminescent lamps can influence signal lines.
- Create a homogeneous reference potential and ground all electrical operating supplies when possible.
 - Please take care for the targeted employment of the grounding actions. The grounding of the PLC is a protection and functionality activity.
 - Connect installation parts and cabinets with the System 300S in star topology with the isolation/protected earth conductor system. So you avoid ground loops.
 - If potential differences between installation parts and cabinets occur, lay sufficiently dimensioned potential compensation lines.

Isolation of conductors

Electrical, magnetically and electromagnetic interference fields are weakened by means of an isolation, one talks of absorption.

Via the isolation rail, that is connected conductive with the rack, interference currents are shunt via cable isolation to the ground. Hereby you have to make sure, that the connection to the protected earth conductor is impedance-low, because otherwise the interference currents may appear as interference cause.

When isolating cables you have to regard the following:

- If possible, use only cables with isolation tangle.
- The hiding power of the isolation should be higher than 80%.
- Normally you should always lay the isolation of cables on both sides. Only by means of the both-sided connection of the isolation you achieve high quality interference suppression in the higher frequency area.
Only as exception you may also lay the isolation one-sided. Then you only achieve the absorption of the lower frequencies. A one-sided isolation connection may be convenient, if:
 - the conduction of a potential compensating line is not possible
 - analog signals (some mV res. μ A) are transferred
 - foil isolations (static isolations) are used.
- With data lines always use metallic or metalized plugs for serial couplings. Fix the isolation of the data line at the plug rack. Do not lay the isolation on the PIN 1 of the plug bar!
- At stationary operation it is convenient to strip the insulated cable interruption free and lay it on the isolation/protected earth conductor line.
- To fix the isolation tangles use cable clamps out of metal. The clamps must clasp the isolation extensively and have well contact.
- Lay the isolation on an isolation rail directly after the entry of the cable in the cabinet. Lead the isolation further on to the System 300S module and **don't** lay it on there again!

**Please regard at installation!**

At potential differences between the grounding points, there may be a compensation current via the isolation connected at both sides.

Remedy: Potential compensation line

General data

Structure/ dimensions

- Peripheral modules with recessed labeling
- Dimensions of the basic enclosure:
1tier width: (WxHxD) in mm: 40x125x120

Reliability

- Wiring by means of spring pressure connections (CageClamps) at the front connector
- Core cross-section 0.08...2.5mm² or 1.5 mm²
- Total isolation of the wiring at module change
- Potential separation of all modules to the backplane bus
- Burst/ESD acc. IEC 61000-4-2/IEC 61000-4-4 (up to level 3)
- Shock resistance acc. IEC 60068-2-6 / IEC 60068-2-27 (1G/12G)

Environmental conditions

- Operating temperature: 0 ... +60°C
- Storage temperature: -25 ... +70°C
- Relative humidity: 5 ... 95% without condensation
- Ventilation by means of a fan is not required

Chapter 2 Analog Input Modules

Overview This chapter contains a description of the structure and the operation of the VIPA analog input modules.

Content	Topic	Page
	Chapter 2 Analog Input Modules	2-1
	Principles.....	2-2
	Parameterization - Basics.....	2-3
	331-1KF01 - AI 8x13Bit	2-6
	331-1KF01 - AI 8x13Bit - Parameterization	2-9
	331-1KF01 - AI 8x13Bit - Technical Data	2-13
	331-7Kx01 - AI 8(2)x12Bit	2-16
	331-7Kx01 - AI 8(2)x12Bit - Parameterization	2-23
	331-7Kx01 - AI 8(2)x12Bit - Diagnostics.....	2-28
	331-7Kx01 - AI 8x12Bit - Technical Data.....	2-34

Principles

Cables for analog signals

For analog signals you have to use isolated cables to reduce interference. The cable screening should be grounded at both ends. If there are differences in the potential between the cable ends, there may occur a potential compensating current that could disturb the analog signals. In this case you should ground the cable screening only at one end.

Connecting test probes

The analog input modules provide variant connecting possibilities for:

- Current sensor
- Voltage sensor
- Resistance thermometer
- Thermocouple
- Resistors



Note!

Please take care of the correct polarity when installing the measuring transducer! Please install short circuits at non-used inputs by connecting the positive contact with the channel ground of the according channel.

Parameterization

The analog input modules from VIPA do not have any measuring range plug.

The modules are parameterized via the hardware configurator or during runtime via SFCs.

Diagnostic functions

The modules that are described in this chapter except the 331-1KF01 offer diagnostics functions.

The following errors may cause diagnostics:

- Error in the project engineering res. parameterization
- Wire break at current measuring
- Measuring range overstep
- Measuring range shortfall
- Common Mode Error
- Lost process interrupt
- Failure of the external power supply

For diagnostic evaluation during runtime, you may use the SFCs 51 and 59. They allow you to request detailed diagnostic information and to react to it.

Parameterization - Basics

Overview

The analog input modules from VIPA do not have any measuring range plug, so the measuring range is to be set by configuration.

There are the following possibilities for parameterization:

- Parameterization by hardware configuration of Siemens SIMATIC manager or with WinPLC7 from VIPA.
- Parameterization during run time by means of SFCs.

Parameterization by hardware configuration

To be compatible to the Siemens SIMATIC manager the following steps are to be accomplished:

- Start the hardware configurator from Siemens
- Create a new project
- Configure your CPU.
- Link-up your System 300V modules in the plugged-in sequence starting with slot 4. Here the analog input modules of VIPA are to be projected as analog input modules of Siemens:

The analog input modules can be found at the hardware catalog at *SIMATIC 300 > SM-300*.

- If needed parameterize the CPU respectively the modules. The parameter window appears as soon as you double click on the according module. At this window the according parameter can be changed.
- Save your project, switch the CPU to STOP and transfer your project to the CPU. As soon as the CPU is switched to RUN the parameters are transferred to the connected modules.

Parameters

The following parameters can be adjusted at the analog input modules:

- Starting address of the input data
- Measuring range, measuring type and integration time
- Diagnostics and interrupt reaction (only 331-7Kx01)

Parameterization during runtime

By using the SFCs 55, 56 and 57 you may change the parameters of the analog modules during runtime via the CPU. The time needed until the new parameterization is valid can last up to a few ms. During this time the measuring value 7FFFh is issued.

The following example shows the assignment of record set 1 to the module 331-7Kx01 during run time.

Example

```

Var
  rec1 array [0...13] of BYTE
  retval      INT
  busy BOOL

Set Record set 1:
L   B#16#0 //Diagnostic disabled
T   #rec1[0]
L   B#16#AA //Interference freq. suppression
T   #rec1[1]
L   B#16#D4 //Meas. range Type S: 0100b
T   #rec1[2] //Meas. type: Thermocouple
T   #rec1[3] //Compensation internal: 1101b
T   #rec1[4] //for all channels
T   #rec1[5]
L   B#16#7F //Upper limit value
T   #rec1[6] //channel 0: 7FFFh
L   B#16#FF
T   #rec1[7]
    .
L   B#16#80 //Upper limit value
T   #rec1[12] //channel 2: 8000h
L   B#16#00
T   #rec1[13]
    
```

Record set 1 from module 331-7Kx01:	
Byte	Bit 7 ... Bit 0
0	Bit 5 ... 0: reserved Bit 6: Diagnosis interrupt release Bit 7: Proc. interrupt release
1	Interference freq. suppression Bit 0, 1: Channel 0/1 Bit 2, 3: Channel 2/3 Bit 4, 5: Channel 4/5 Bit 6, 7: Channel 6/7
2	Mode Channel 0/1 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
3	Mode Channel 2/3 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
4	Mode Channel 4/5 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
5	Mode Channel 6/7 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
6, 7	Upper limit value Channel 0
8, 9	Lower limit value Channel 0
10, 11	Upper limit value Channel 2
12, 13	Lower limit value Channel 2


Transfer with SFC 55 "WR_PARM" Record set 1to Module:

```

Call   "WR_PARM" //call SFC 55
REQ    :=TRUE //write request
IOID   :=B#16#54 //identifier for the address space: peripheral input
LADDR  :=W#16#100 //logical base address: 256
RECNUM :=B#16#1 //record number 1
RECORD :=#rec1 //record for Record set 1
RET_VAL :=#retval //return value (0: no error <>0: error code)
BUSY   :=#busy //BUSY = 1: the write operation has not been completed
    
```

Get mode

As shown in the following illustration the parameter *mode* is made up of the coding of the *measuring range* and *measuring type* during run time parameterization each channel respectively channel group.



The corresponding codes can be found at *parameterization* of each module.

The table is divided into *measuring type* like voltage, current, resistance measuring... . Here the corresponding binary code of the *measuring type* may be found.

Within the *measuring types* there are the *measuring ranges*, for which a binary *measuring range code* is to be specified in each case.

Example

Referring to the example specified above the mode is determined in the following:

Given: Measuring type: Thermocouple, compensation internal, linear
 Measuring range: Type S

For the module 331-7Kx01 results from the table in the case of "Thermocouple with compensation internal, linear" the binary coding for measuring type: 1101b.

For Measuring range "Type S" the binary measuring range coding results as: 0100b.

By joining the two binary values you receive the following byte as *mode*: 1101 0100b = D4h.



Attention!

Please regard that the modules described here do not have hardware precautions against wrong parameterization res. wrong wiring. The setting of the according measuring range is exclusively at the project engineering.

For example, the modules may get a defect if you connect a voltage at parameterized current measuring.

At the project engineering you should be very careful.

Please regard also that disconnecting res. connecting during operation is not possible!

331-1KF01 - AI 8x13Bit

Order data AI 8x13Bit VIPA 331-1KF01


Description The analog input module transforms analog signals from the process into digital signals for the internal processing. The module is pin and function compatible to the known module from Siemens. Plugging and unplugging during operation, is not supported. Voltage and current encoders, resistors and resistor thermometers may be connected as sensors

- Properties**
- 8 inputs
 - Measuring value resolution 12bit + sign
 - Isolated to the backplane bus



Default configuration After Power ON the module has the following default configuration. These can be changed by hardware configuration.

- measuring range: $\pm 10V$ for all channels
- integration time: 60ms

Structure




Pin assignment	Pin	Assignment	Connection
	1	U+ channel 0	1 U+
	2	I+ channel 0	2 I+
	3	S- channel 0	3 S-
	4	M+ channel 0	4 M+
	5	M- channel 0	5 M-
	6	U+ channel 1	6 U+
	7	I+ channel 1	7 I+
	8	S- channel 1	8 S-
	9	M+ channel 1	9 M+
	10	M- channel 1	10 M-
	11	U+ channel 2	11 U+
	12	I+ channel 2	12 I+
	13	S- channel 2	13 S-
	14	M+ channel 2	14 M+
	15	M- channel 2	15 M-
	16	U+ channel 3	16 U+
	17	I+ channel 3	17 I+
	18	S- channel 3	18 S-
	19	M+ channel 3	19 M+
	20	M- channel 3	20 M-
	21	U+ channel 4	21 U+
	22	I+ channel 4	22 I+
	23	S- channel 4	23 S-
	24	M+ channel 4	24 M+
	25	M- channel 4	25 M-
	26	U+ channel 5	26 U+
	27	I+ channel 5	27 I+
	28	S- channel 5	28 S-
	29	M+ channel 5	29 M+
	30	M- channel 5	30 M-
	31	U+ channel 6	31 U+
	32	I+ channel 6	32 I+
	33	S- channel 6	33 S-
	34	M+ channel 6	34 M+
	35	M- channel 6	35 M-
	36	U+ channel 7	36 U+
	37	I+ channel 7	37 I+
	38	S- channel 7	38 S-
	39	M+ channel 7	39 M+
	40	M- channel 7	40 M-



Wiring diagrams

The following illustration shows the connection options for the different measuring ranges. The assignment to the measuring ranges is to find in the column "Conn." of the table "Measuring" on the next pages.



Note!

Please take care that the maximum permissible common-mode voltage of 2V between the inputs at connection of voltage and current givers is not exceeded. To avoid wrong measurements you connect the individual connections M- with each other.

At measuring of resistances and resistance thermometers a connection of the M- connections is not required.

Temporarily not used inputs with activated channel must be connected with the concerning ground. When not used channels are deactivated this is not necessary.

Representation of analog values

Analog values are exclusively processed by the CPU in a binary format. For this the analog module transforms every process signal into a digital and transfers this as word to the CPU.

At similar nominal range, the digitalized analog value for in- and output is identical.

Resolution

Because the resolution of the module is 12Bit plus sign-Bit, the not used low value positions (3 Bit) are filled with "0".

For the sign Bit is valid:

Bit 15 = "0" → positive value

Bit 15 = "1" → negative value

Resolution	Analog value															
	High byte								Low byte							
Bit number	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Value	SG	2 ¹⁴	2 ¹³	2 ¹²	2 ¹¹	2 ¹⁰	2 ⁹	2 ⁸	2 ⁷	2 ⁶	2 ⁵	2 ⁴	2 ³	2 ²	2 ¹	2 ⁰
12bit + sign	SG	Measuring value												0	0	0

331-1KF01 - AI 8x13Bit - Parameterization

- Overview** After Power ON the module is set to $\pm 10V$ for all channels with an integration time of 60ms.
Via a hardware configuration you may parameterize the channels individually.
- Place module**
- Start the hardware configurator with the project the analog modules are to be configured.
 - To place the analog module open the hardware catalog. There the module can be found at SIMATIC 300/SM-300/AI-300, order no.: 6ES7 331-1KF01-0AB0.
 - Choose the according module and drag & drop it to the concerning slot in the hardware configurator.
- Parameterize the module** Via double click on the wanted module in the hardware configurator you open the concerning parameter window.
You may alter the following parameters:
- Start address of the data of the module stored in the CPU
 - Measuring range, measuring type and integration times for all of the 8 channels
- Save and transfer project**
- Save and compile your project
 - Set your CPU to STOP
 - Transfer your project into the CPU
- As soon as you switch the CPU into RUN, the parameters are transmitted to the analog input module.
- More detailed information about the parameters can be found on the following pages.

Structure of parameter byte (Record set 1)

At the parameterization, a parameter area of 14byte length is stored in the record set 1. Under deploying the SFCs 55, 56 and 57, you may alter the parameters during run time and transfer them to your analog module.

Record set 1 (Byte 0 to 13):

Byte	Bit 7 ... Bit 0
0	Temperature measuring: 0000 0000b: Grad Celsius 0000 1000b: Grad Fahrenheit 0001 0000b: Kelvin
1	Interference frequency suppression: 0000 0001b: 60Hz (50ms Integration time) 0000 0010b: 50Hz (60ms Integration time)
2	Mode channel 0 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
3	Mode channel 1 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
4	Mode channel 2 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
5	Mode channel 3 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
6	Mode channel 4 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
7	Mode channel 5 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
8	Mode channel 6 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
9	Mode channel 7 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type
10	Temperature coefficient: Bit 3 ... 0: channel 1 Bit 7 ... 4: channel 0
11	Temperature coefficient: Bit 3 ... 0: channel 3 Bit 7 ... 4: channel 2
12	Temperature coefficient: Bit 3 ... 0: channel 5 Bit 7 ... 4: channel 4
13	Temperature coefficient: Bit 3 ... 0: channel 7 Bit 7 ... 4: channel 6

Diagram illustrating the bit fields for measuring type and measuring range. The bit fields are: Bit 7 (measuring type), Bits 6-4 (measuring range), Bit 3 (measuring type), and Bits 2-0 (measuring range).


The according coding of measuring range and measuring type is described on the following pages.

To deactivate a channel the code 0000 0000 is used.


At temperature measurement a temperature coefficient is required. The table shows the according coefficient:

Measurment range	Temperature coefficient	Coding each channel
Pt 100	Pt 0.003850Ω/Ω°C (ITS-90)	0100b
Ni100 Ni1000	Ni 0.006180Ω/Ω°C	1000b
LG-Ni 1000	Ni 0.005000Ω/Ω°C	1010b

Mode per Channel



The following section shows an overview of all measuring types and ranges plus binary coding for the parameterization. Additionally, the wiring diagram assigned to the measuring range is shown in brackets.



Measuring type Voltage measuring (Measuring type coding: 0001b)

Measuring range (Connection)	Measuring range / Representation	Measuring range coding
+/- 50mV (Connection 3)	58.79mV = End Overdrive region (32511)	0001b
	- 50...50mV = Nominal range (-27648...27648)	
	- 58.79mV = End Underdrive region (-32512)	
+/- 500mV (Connection 3)	587.9mV = End Overdrive region (32511)	0011b
	- 500...500mV = Nominal range (-27648...27648)	
	- 587.9mV = End Underdrive region (-32512)	
+/- 1V (Connection 3)	1.176V = End Overdrive region (32511)	0100b
	- 1...1V = Nominal range (-27648...27648)	
	- 1.175V = End Underdrive region (-32512)	
+/- 5V (Connection 1)	5.879V = End Overdrive region (32511)	0110b
	- 5...5V = Nominal range (-27648...27648)	
	- 5.879V = End Underdrive region (-32512)	
1... 5V (Connection 1)	5.704V = End Overdrive region (32511)	0111b
	1...5V = Nominal range (0...27648)	
	0.296V = End Underdrive region (- 4864)	
0 ... 10V (Connection 1)	11.759V = End Overdrive region (32511)	1000b
	0...10V = Nominal range (0...27648)	
	-1.759V = End Underdrive region (- 4864)	
+/- 10V (Connection 1)	11.759V = End Overdrive region (32511)	1001b
	- 10...10V = Nominal range (-27648...27648)	
	- 11.759V = End Underdrive region (-32512)	

Measuring type Current measuring (Measuring type coding: 0010b)

Measuring range (Connection)	Measuring range / Representation	Measuring range coding
0... 20mA (Connection 2)	23.52mA = End Overdrive region (32511)	0010b
	0...20mA = Nominal range (0...27648)	
	- 3.52mA = End Underdrive region (-4864)	
4... 20mA (Connection 2)	22.81mA = End Overdrive region (32511)	0011b
	4...20mA = Nominal range (0...27648)	
	1.185mA = End Underdrive region (-4864)	
+/- 20mA (Connection 2)	23.52mA = End Overdrive region (32511)	0100b
	- 20...20mA = Nominal range (-27648...27648)	
	- 23.52mA = End Underdrive region (-32512)	

Measuring type Resistance measuring (Measuring type coding: 0101b)

Measuring range (Connection)	Measuring range / Representation	Measuring range coding
600 Ohm (Connect. 4, 5, 6)	705.53 Ohm = End Overdrive region (32511)	0110b
	0...600 Ohm = Nominal range (0...27648)	
	negative values physically not possible	
6000 Ohm (Connect. 4, 5, 6)	7055.3 Ohm = End Overdrive region (32511)	1000b
	0...6000 Ohm = Nominal range (0...27648)	
	negative values physically not possible	

Measuring type Thermo resistance measuring (**Measuring type coding: 1001b**),
wiring diagram (Conn.: 4, 5, 6)

Meas. range	°C (0.1°C/digit)	Unit dec.	°F (0.1°F/digit)	Unit dec.	K (0.1K/digit)	Unit dec.	Range	Range coding
Pt100 Standard	1000.0	10000	1832.0	18320	1273.2	12732	End Overdrive region	0010b
	850.0	8500	1562	15620	1123.2	11232	Nominal range	
		
	-200.0	-2000	-328.0	-3280	73.2	732	End Under-drive region	
	-243.0	-2430	-405.4	-4054	30.2	302		
Meas. range	°C (0.01°C/digit)	Unit dec.	°F (0.01°F/digit)	Unit dec.	K	Unit dec.	Range	Range coding
Pt100 Climate	155.00	15500	311.00	31100	-	-	End Overdrive region	0000b
	130.00	13000	266.00	26600	-	-	Nominal range	
	-	-		
	-120.00	-12000	-184.00	-18400	-	-	End Under-drive region	
	-145.00	-14500	-229.00	-22900	-	-		
Meas. range	°C (0.1°C/digit)	Unit dec.	°F (0.1°F/digit)	Unit dec.	K (0.1K/digit)	Unit dec.	Range	Range coding
Ni100 Standard	295.0	2950	563.0	5630	568.2	5682	End Overdrive region	0011b
	250.0	2500	482.0	4820	523.2	5232	Nominal range	
		
	-60.0	-600	-76.0	-760	213.2	2132	End Under-drive region	
	-105.0	-1050	-157.0	-1570	168.2	1682		
Meas. range	°C (0.01°C/digit)	Unit dec.	°F (0.01°F/digit)	Unit dec.	K	Unit dec.	Range	Range coding
Ni100 Climate	295.00	29500	327.66	32766	-	-	End Overdrive region	0001b
	250.00	25000	280.00	28000	-	-	Nominal range	
	-	-		
	-60.00	-6000	-76.00	7600	-	-	End Under-drive region	
	-105.00	-10500	-157.00	-15700	-	-		
Meas. range	°C (0.1°C/digit)	Unit dec.	°F (0.1°F/digit)	Unit dec.	K (0.1K/digit)	Unit dec.	Range	Range coding
Ni 1000 / LG-Ni 1000 Standard	295.0	2950	563.0	5630	568.2	5682	End Overdrive region	0110b
	250.0	2500	482.0	4820	523.2	5232	Nominal range	
		
	-60.0	-600	-76.0	-760	213.2	2132	End Under-drive region	
	-105.0	-1050	-157.0	-1570	168.2	1682		
Meas. range	°C (0.01°C/digit)	Unit dec.	°F (0.01°F/digit)	Unit dec.	K	Unit dec.	Range	Range coding
Ni 1000 / LG-Ni 1000 Climate	295.00	29500	327.66	32766	-	-	End Overdrive region	1010b
	250.00	25000	280.00	28000	-	-	Nominal range	
	-	-		
	-60.00	-6000	-76.00	7600	-	-	End Under-drive region	
	-105.00	-10500	-157.00	-15700	-	-		

When exceeding the overdrive region 32767 (7FFFh) is issued, falling below the underdrive region -32768 (8000h) is issued.

331-1KF01 - AI 8x13Bit - Technical Data

Order number	331-1KF01
Type	SM 331
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	255 mA
Power loss	1.3 W
Technical data analog inputs	
Number of inputs	8
Cable length, shielded	50 m
Rated load voltage	-
Current consumption from load voltage L+ (without load)	-
Voltage inputs	✓
Min. input resistance (voltage range)	100 k Ω
Input voltage ranges	-50 mV ... +50 mV -500 mV ... +500 mV -1 V ... +1 V -5 V ... +5 V 0 V ... +10 V -10 V ... +10 V +1 V ... +5 V
Operational limit of voltage ranges	+/-0.5% ... +/-0.6%
Basic error limit voltage ranges with SFU	+/-0.3% ... +/-0.4%
Current inputs	✓
Min. input resistance (current range)	100 Ω
Input current ranges	-20 mA ... +20 mA 0 mA ... +20 mA +4 mA ... +20 mA
Operational limit of current ranges	+/-0.5%
Basic error limit current ranges with SFU	+/-0.3%
Resistance inputs	✓
Resistance ranges	0 ... 600 Ohm 0 ... 6000 Ohm
Operational limit of resistor ranges	+/-0.5%
Basic error limit	+/-0.3%
Resistance thermometer inputs	✓
Resistance thermometer ranges	Pt100 Ni100 Ni1000
Operational limit of resistance thermometer ranges	+/-1K ... +/-1.2K
Basic error limit thermoresistor ranges	+/-0.8K
Thermocouple inputs	-
Thermocouple ranges	-
Operational limit of thermocouple ranges	-
Basic error limit thermoelement ranges	-
Programmable temperature compensation	-
External temperature compensation	-
Internal temperature compensation	-
Resolution in bit	13
Measurement principle	Sigma-Delta
Basic conversion time	61 ms/51 ms / channel
Noise suppression for frequency	50 Hz/60 Hz
Initial data size	16 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	no

Order number	331-1KF01
Process alarm	no
Diagnostic interrupt	no
Diagnostic functions	no
Diagnostics information read-out	none
Supply voltage display	none
Group error display	none
Channel error display	none
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	-
Max. potential difference between circuits	-
Max. potential difference between inputs (Ucm)	DC 2 V
Max. potential difference between Mana and Mintern (Uiso)	-
Max. potential difference between inputs and Mana (Ucm)	-
Max. potential difference between inputs and Mintern (Uiso)	DC 75 V/ AC 60 V
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	16
Output bytes	0
Parameter bytes	21
Diagnostic bytes	0
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	260 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

Additional Technical Data

Order number	VIPA 331-1KF01		
Voltages, Currents, Potentials			
Constant current for resistance-type sensor			
- resistance thermometer and resistance measurement 0 ... 600Ω	0.83mA		
- resistance measurement 0 ... 6kΩ	0.25mA		
Analog value generation			
Integration time / conversion time / resolution (per channel)			
- programmable	yes		
- Integration time in ms	60ms		50ms
additional conversion time for measuring resistance in ms	61ms		51ms
Suppression of interference, limits error			
Noises suppression for $f=n \times (f1 \pm 1\%)$ ($f1$ =interference frequency, $n=1,2,\dots$)			
- Common-mode interference ($U_{CM} < 2V$)	> 86dB		
- Series-mode noise (peak value of noise < nominal value of input range)	> 40dB		
Temperature error (with reference to the input range)	$\pm 0.005\%/K$		
Linearity error (with reference to the input range)	$\pm 0.02\%$		
Repeatability (in steady state at 25°C, with reference to the input range)	$\pm 0.05\%$		
Data for selecting a sensor			
	Input range	Input resistance	
- Voltage	$\pm 50mV, \pm 500mV, \pm 1V$	100MΩ	
	$\pm 5V, 1...5V, \pm 10V, 0...10V$	100kΩ	
- Current	$\pm 20mA, 0...20mA, 4...20mA$	100Ω	
- Resistors	0 ... 600Ω, 0 ... 6kΩ	100MΩ	
- Resistance thermometer	Pt100 Standard / Climate	100MΩ	
	Ni100, Ni1000, LG-Ni1000	100MΩ	
	Standard / Climate		
Maximum input voltage for voltage input U+ (destruction limit)	max. 30V		
Maximum input voltage for voltage input M+ (destruction limit)	max. 12V 30V for max. 1s		
Maximum input current for current input L+ (destruction limit)	40mA		
Connection of the sensors			
- for measuring voltage	possible		
- for measuring current	possible, with external supply		
as 2wire transmitter	possible		
as 4wire transmitter	possible		
- for measuring resistance	possible		
with 2conductor connection	possible		
with 3conductor connection	possible		
with 4conductor connection	possible		
Characteristic linearization	yes		
- for RTD	Pt100 Standard / Climate Ni100, Ni1000, LG-Ni1000 Standard / Climate		
Technical unit for temperature measurement	°C/K/F		

331-7Kx01 - AI 8(2)x12Bit

Order data	AI 8x12Bit	VIPA 331-7KF01
	AI 2x12Bit	VIPA 331-7KB01


Description The analog input modules transform analog signals from the process into digital signals for the internal processing. The modules are pin and function compatible to the modules from Siemens with the same name.

Please regard that contrary to the Siemens modules the modules specified here do not have any measuring range plug. The attitude of the designated measuring range exclusively takes place during software project engineering. Plugging and unplugging during operation, is not supported. Voltage and current sensors, thermocouples, resistors and resistance thermometers may be connected.

- Properties**
- 8 inputs in 4 channel group (331-7KF01)
 - 2 inputs in 1 channel group (331-7KB01)
 - Measuring value resolution 14Bit + sign
 - Configurable diagnostic and process interrupt
 - Isolated to the backplane bus

- Measuring range after Power ON** After Power ON both modules have the following default configuration. These can be changed by hardware configuration:
- measuring range: $\pm 10V$ for all channels
 - integration time: 20ms
 - Interrupts deactivated

Structure



Pin assignment status monitor

Pin	Assignment	Connection	331-7KF01	LED	Description	
1	Power supply DC 24V			SF	LED (red) Group error, ON as soon as a diagnostic entry is present respectively during missing external voltage supply	
2	+ Channel 0			F0	F0...7	LED (red) Channel error, ON together with SF if error respectively overflow measuring range per channel
3	Ground Channel 0			F1		
4	+ Channel 1			F2		
5	Ground Channel 1			F3		
6	+ Channel 2			F4		
7	Ground Channel 2			F5		
8	+ Channel 3			F6		
9	Ground Channel 3			F7		
10	+ Compensation slot					
11	Ground Compens. slot					
12	+ Channel 4					
13	Ground Channel 4					
14	+ Channel 5					
15	Ground Channel 5					
16	+ Channel 6					
17	Ground Channel 6					
18	+ Channel 7					
19	Ground Channel 7					
20	Ground					

Pin	Assignment	Connection	331-7KB01	LED	Description	
1	Power supply DC 24V			SF	LED (red) Group error, ON as soon as a diagnostic entry is present respectively during missing external voltage supply	
2	+ Channel 0			F0	F0 F1	LED (red) Channel error, ON together with SF if error respectively overflow measuring range per channel
3	Ground Channel 0			F1		
4	+ Channel 1					
5	Ground Channel 1					
6	n.c.					
7	.					
8	.					
9	.					
9	n.c.					
10	+ Compensation slot					
11	Ground Compens. slot					
12	n.c.					
13	.					
14	.					
15	.					
16	.					
19	n.c.					
20	Ground					

Connection of sensors

Regarding the fact, that parameterized inputs can be left unused due to the building of channel groups, you have to connect the unused inputs with the associated ground.

If you want to use the internal compensation when deploying thermocouples, the 2 COMP inputs have to be bridged too.

In the following all connection types of sensors for a pair of channels are specified.

Installation of current sensors


Current sensors as 2wire or 4wire measuring transducer

The 2wire measuring transducer gets the supply voltage (13V at 30mA) short-circuit resistant via the clamps of the analog input module. The 2wire measuring transducer transduces the measuring value into a current.

With use of 2wire measuring transducer with a voltage >13V you may connect in line an external power supply. But here you have to deactivate the internal power supply, by selecting 4wire operation during hardware configuration.


2wire measuring transducer

The following picture illustrates the connection of 2wire measuring transducers with internal respectively external power supply:




4wire measuring transducer

Please regard that the 4wire measuring transducers have to be provided external.



Installation of voltage sensors

The following picture shows the installation of voltage sensors at a channel pair of a potential separated analog input module:



M+: measuring line (positive)
M-: measuring line (negative)

Installation of thermocouples AI 8(2)x12Bit

The thermo pair consists of two wires of different metals or metal alloys which are soldered or welded together at the ends. The different combinations of metals cause different thermocouple types, e.g. K, J, N.

Operating basics

Independent from the type of the thermocouple the principle of measuring is identical for all types:

When the measuring point has another temperature than the free ends of the thermo pair (connection point), a voltage occurs between the free ends, the thermo voltage.

The amount of the thermo voltage depends on the difference between the temperature at the measuring point and the temperature at the free ends. For a thermo pair always records a temperature difference, the free ends have to be set on a comparison point with known temperature, to determine the temperature at the measuring point.

Extension to a comparison point


The thermo pairs may be extended from your connecting point to a point with known temperature (comparison point) via compensating lines.

The compensating lines have the same material as the wires of the thermocouple. The leads are out of copper. In this case you should use the external compensation. Please regard pole correct installation, for this may cause enormous measuring errors.


Installation variants

The following pictures show the different installation possibilities of thermocouple with and without compensation slot.

Thermocouples without compensation slot and internal compensation



Thermocouples without compensation slot and external compensation




M+: measuring line (positive)
M-: measuring line (negative)

COMP+: Compensation connection (positive)
COMP-: Compensation connection (negative)

When connecting thermocouples without compensation slot and parameterized internal compensation, the temperature compensation happens via a temperature sensor in the module per channel pair. At external compensation, thermocouples with integrated compensation have to be used.

Thermocouples with compensation slot




When connecting thermocouples with one compensation slot, you have to regard that the thermocouples have the same type.

The compensation slot is to be connected at COMP+ and COMP- and is to be supplied external.

Installation of resistance thermometers and resistors

The installation of resistance thermometers/resistors needs 4wires. Via the connections I_{C+} and I_{C-} the resistance thermometer/resistor gets a constant current. The voltage occurring at the resistor thermometer/resistor is measured via the connections M+ and M-.



- M+: measuring line (positive)
- M-: measuring line (negative)
- I_{C+} : constant current line (positive)
- I_{C-} : constant current line (negative)

By appropriate bridges on the module between M+ and I_{C+} respectively M- and I_{C-} you can attach also resistance thermometers in 2- and 3wire technique. Due to the not considered conduit length you have to count on losses of accuracy with the result of the measurement.

Channel allocation

At "resistance thermometers-/resistors measuring" the whole channel group (both channels) are used. The measured value can be found at the area of the 1. channel of the group. The 2. channel of the group is predefined with the overflow value "7FFFh".

Thermocouples with Pt100 reference junction (since firmware V1.3.8)


Starting with firmware version 1.3.8 of the analog module, there is the possibility to connect a Pt100 reference junction for compensation.

With this connection variant the temperature of the reference junction is evaluated by means of a Pt100 resistance thermometer. For this the channel group tied up to Pt100 reference junction is to be parameterized as "Pt100 reference junction". Only one channel group may be parameterized as "Pt100 reference junction".

Every channel, which is parameterized on "thermocouple with external compensation", uses the temperature of the Pt100 reference junction for evaluation.

Compared to the compensating box there is the possibility to use thermocouples of different type at the same time. The temperature evaluation is more exactly than internal compensation, too.

Since this variant is not supported by the Siemens SIMATIC manager, the parameterization only takes place exclusively at run time.



- M+: measuring line (positive)
- M-: measuring line (negative)
- I_{C+}: constant current line (positive)
- I_{C-}: constant current line (negative)

*) With a wire break at the Pt100 reference junction for evaluation, the 1. channel of one group shows the value 7FFFh.

Connection Pt100 reference junction

The installation of the Pt100 reference junction needs 4 wires. By appropriate bridges on the module between M+ and I_{C+} respectively M- and I_{C-} you also may attach Pt100 in 2- and 3wire technique. Due to the not considered conduit length you have to count on losses of accuracy with the result of the measurement.

Here via the connections I_{C+} and I_{C-} the Pt resistance thermometer gets a constant current. The voltage occurring at the Pt100 resistor thermometer is measured via the connections M+ and M-.

Channel allocation

At Pt100 reference junction the whole channel group (both channels) are used. The measured value can be found at the area of the 1. channel of the group. The 2. channel of the group is predefined with the overflow value "7FFFh".

Every channel, which is parameterized on "thermocouple with external compensation", uses this measuring value for evaluation even in a case of a wire break it contains the value 7FFFh.

Analog value representation

The analog values are only processed by the CPU in binary representation. Hereby the process signals are transformed into digital format in the analog module and passed on to the CPU as word variable.

The digitized analog value is the same for input and output values at the same nominal range.

Resolution

The resolution of an analog value is 14 Bit plus sign Bit. Bit 15 serves as sign bit (SG) with the meaning:

Bit 15 = "0" → positive value

Bit 15 = "1" → negative value

Depending upon parameterized interference frequency (integration time) the modules offers different resolutions. The not used low byte bits are set to "0".

Resolution	Analog value															
	High byte								Low byte							
Bit number	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Value	SG	2 ¹⁴	2 ¹³	2 ¹²	2 ¹¹	2 ¹⁰	2 ⁹	2 ⁸	2 ⁷	2 ⁶	2 ⁵	2 ⁴	2 ³	2 ²	2 ¹	2 ⁰
14bit + sign	SG	Measuring value (interference frequency 10Hz)														0
12bit + sign	SG	Measuring value (interference frequency 50, 60Hz)											0	0	0	
9bit + sign	SG	Measuring value (interference frequency 400Hz)									0	0	0	0	0	0



Note!

This resolution does not apply to temperature levels. The converted temperature levels are the result of a conversion of the analog module.

Behavior at over- and underflow

As soon as a measured value exceeds the overdrive region and/or falls below the underdrive region, the following value is issued:

Measuring value > end of overdrive region: 32767 (7FFFh)

Measuring value < end of underdrive region: -32768 (8000h)

331-7Kx01 - AI 8(2)x12Bit - Parameterization

Overview

After power ON every channel of the modules is adjusted to $\pm 10V$ with an interference frequency of 50Hz. The diagnostic function is deactivated.

At the parameterization, a record set of 16byte length is transferred to both modules. Here the AI 2x12Bit (331-7KB01) uses the parameters for the channel group 0/1 the parameters for further channel groups are ignored.



Note!

Parameters which are not supported by the Siemens hardware configurator may only be changed during run time by means of SFCs.

Install module

- Start the hardware configurator and load your project for the analog module.
- Open the hardware catalog to install the analog input module. In the hardware catalog the analog modules with the order-no.: 6ES7 331-7KB01 (2x12Bit) and 6ES7 331-7KF01 (8x12Bit) can be found at SIMATIC 300/SM-300/AI-300.
- Choose the according module and drag & drop this module to the concerning slot in the hardware configurator.

Parameterize the module

Via double click on the wanted module in the hardware configurator you open the concerning parameter window.

You can change the following module parameters:

- Starting address for CPU mapping
- Measuring ranges, measuring type and integration times for channel pairs
- Process interrupt at limit value overflow for channel 0 and channel 2
- Limit value action at overflow
- Diagnosis and group diagnosis for each channel pair at wire break or measuring range over-/underflow.

Save and transfer your project

- Save and translate your project
- Switch your CPU in STOP
- Transfer your project into the CPU

As soon as you switch the CPU into RUN, the parameters are transmitted to the analog input module.

More information about the parameters can be found at the following pages.

**Structure of the parameter bytes
Record set 0,
Record set 1**

At the parameterization, a parameter area of 16byte length is stored in the record sets 0 and 1. Here the data irrelevant for the module AI 2x12Bit (331-7KB01) are ignored.

Using the SFCs 55, 56 and 57 you can only change parameters at record set 1 and transfer during runtime to the analog module. On this way parameters may be transferred which are not supported by the Siemens SIMATIC manager, as e.g. setting of high temperature measuring ranges.

**Parameter
Record set 0**
(not parameterizable via SFC)


Record set 0 (Byte 0 to 1):

Byte	Bit 7 ... Bit 0	Default
0	Group diagnosis bit coded Bit 0: Channel 0/1 Bit 1: Channel 2/3 Bit 2: Channel 4/5 Bit 3: Channel 6/7 Bit 7 ... 4: reserved	00h
1	Wire break test bit coded Bit 0: Channel 0/1 Bit 1: Channel 2/3 Bit 2: Channel 4/5 Bit 3: Channel 6/7 Bit 7 ... 4: reserved	00h

**Parameter
Record set 1**
(parameterizable via SFC)

Record set 1 (Byte 0 to 13):

Byte	Bit 7 ... Bit 0	Default
0	Bit 5 ... 0: reserved Bit 6: Diagnostic interrupt release Bit 7: Process interrupt release	00h
1	Interference frequency suppression Bit 0, 1: Channel 0/1 Bit 2, 3: Channel 2/3 Bit 4, 5: Channel 4/5 Bit 6, 7: Channel 6/7	AAh
2	Mode Channel 0/1 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	19h (+/-10V)
3	Mode Channel 2/3 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	19h (+/-10V)
4	Mode Channel 4/5 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	19h (+/-10V)
5	Mode Channel 6/7 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	19h (+/-10V)
6, 7	Upper limit value Channel 0	7FFFh
8, 9	Lower limit value Channel 0	8000h
10, 11	Upper limit value Channel 2	7FFFh
12, 13	Lower limit value Channel 2	8000h



For the according coding of measuring range and measuring type see "Modus per channel" at the following pages.



Note for deactivating a channel group!

With the Coding 0000 0000 a channel group may be deactivated.

Modus per channel pair

The following section shows an overview of all measuring types and ranges plus binary coding for the parameterization.

Measuring type Voltage measuring (Measuring type coding: 0001b)

Measuring range	Range / Representation	Range coding
+/- 80mV	94.071mV = End Overdrive region (32511) - 80...80mV = Nominal range (-27648...27648) - 94.074mV = End Underdrive region (-32512)	0001b
+/- 250mV	293.97mV = End Overdrive region (32511) - 250...250mV = Nominal range (-27648...27648) - 293.98mV = End Underdrive region (-32512)	0010b
+/- 500mV	587.94mV = End Overdrive region (32511) - 500...500mV = Nominal range (-27648...27648) - 587.96mV = End Underdrive region (-32512)	0011b
+/- 1V	1.175V = End Overdrive region (32511) - 1...1V = Nominal range (-27648...27648) - 1.175V = End Underdrive region (-32512)	0100b
+/- 2.5V	2.939V = End Overdrive region (32511) - 2.5...2.5V = Nominal range (-27648...27648) - 2.933V = End Underdrive region (-32512)	0101b
+/- 5V	5.879V = End Overdrive region (32511) - 5...5V = Nominal range (-27648...27648) - 5.879V = End Underdrive region (-32512)	0110b
+/- 10V	11.758V = End Overdrive region (32511) - 10...10V = Nominal range (-27648...27648) - 11.759V = End Underdrive region (-32512)	1001b
1... 5V	5.703V = End Overdrive region (32511) 1...5V = Nominal range (0...27648) 0.296V = End Underdrive region (- 4864)	0111b

Measuring type 4wire Current measuring (Measuring type coding: 0010b)

Measuring range	Range / Representation	Range coding
+/- 3.2mA	3.762mA = End Overdrive region (32511) - 3.2...3.2mA = Nominal range (-27648...27648) - 3.762mA = End Underdrive region (-32512)	0000b
+/- 10mA	11.758mA = End Overdrive region (32511) - 10...10mA = Nominal range (-27648...27648) - 11.758mA = End Underdrive region (-32512)	0001b
+/- 20mA	23.515mA = End Overdrive region (32511) - 20...20mA = Nominal range (-27648...27648) - 23.515mA = End Underdrive region (-32512)	0100b
0... 20mA	23.515mA = End Overdrive region (32511) 0...20mA = Nominal range (0...27648) - 3.518mA = End Underdrive region (-4864)	0010b
4... 20mA	22.810mA = End Overdrive region (32511) 4...20mA = Nominal range (0...27648) 1.185mA = End Underdrive region (-4864)	0011b

Measuring type 2wire Current measuring (Measuring type coding: 0011b)

Measuring range	Range / Representation	Range coding
4... 20mA	22.810mA = End Overdrive region (32511) 4...20mA = Nominal range (0...27648) 1.185mA = End Underdrive region (-4864)	0011b

Measuring type 4wire Resistance measuring (Measuring type coding: 0100b)

Measuring range	Range / Representation	Range coding
150 Ohm	176.383 Ohm = End Overdrive region (32511) 0...150 Ohm = Nominal range (0...27648) negative values physically not possible	0010b
300 Ohm	352.767 Ohm = End Overdrive region (32511) 0...300 Ohm = Nominal range (0...27648) negative values physically not possible	0100b
600 Ohm	705.534 Ohm = End Overdrive region (32511) 0...600 Ohm = Nominal range (0...27648) negative values physically not possible	0110b

Measuring type 4wire Thermo resistance (Measuring type coding: 1000b)

Measuring range	Range / Representation	Range coding
Pt100 Standard	1000°C = End Overdrive region (10000) - 200...850°C = Nominal range (-2000...8500) - 243°C = End Underdrive region (-2430) (0.1°C/digit)	0010b
Pt100 Climate	155°C = End Overdrive region (15500) - 120...130°C = Nominal range (-12000...13000) - 145°C = End Underdrive region (-14500) (0.01°C/digit)	0000b
Pt 100 reference junction	1000 = End Overdrive region (10000) -100...200 = Nominal range (-1000...2000) -243 = End Underdrive region (-2430) (0.1°C/Digit)	1101b ²⁾
Ni100 Standard	295°C = End Overdrive region (2950) - 60...250°C = Nominal range (-600...2500) - 105°C = End Underdrive region (-1050) (0.1°C/digit)	0011b ¹⁾
Ni100 Climate	295°C = End Overdrive region (29500) - 60...250°C = Nominal range (-6000...25000) - 105°C = End Underdrive region (-10500) (0.01°C/digit)	0001b

¹⁾ Please use up to the firmware version V.1.2.6 of the analog module the coding 1011b. The current firmware version may be found at the front flap beneath the label strip.

²⁾ The measuring range Pt100 reference junction is available starting with firmware version V. 1.3.8. Since this measuring range is not supported by the Siemens SIMATIC manager, the parameterization only takes place exclusively at run time.

Measuring type Thermocouple:

compensation external, linear (Measuring type coding: 1110b)

compensation internal, linear (Measuring type coding: 1101b)

Measuring range	Range / Representation in °C (0.1°C/digit)	Range coding
Type J [Fe-Cu-Ni IEC]	1450°C = End Overdrive region (14500) -210...1200°C = Nominal range (-2100... 12000) -210°C = End Underdrive region (-2100)	0101b
Type K [Ni-Cr-Ni]	1622°C = End Overdrive region (16220) -270... 1372°C = Nominal range (-2700... 13720) -270°C = End Underdrive region (-2700)	1000b
Type N [Ni-Cr-Si]	1550°C = End Overdrive region (15500) -270...1300°C = Nominal range (-2700...13000) -270°C = End Underdrive region (-2700)	0001b
Type E [Ni-Cr - Cu-Ni]	1200°C = End Overdrive region (12000) -270...1000°C = Nominal range (-2700...10000) -270°C = End Underdrive region (-2700)	0010b
Type L [Fe-Cu-Ni]	1150°C = End Overdrive region (11500) -200...900°C = Nominal range (-2000...9000) -200°C = End Underdrive region (-2000)	0110b
Type T [Cu-Cu-Ni]	540 = End Overdrive region (5400) -270...400 = Nominal range (-2700...4000) -270 = End Underdrive region (-2700)	0111b ¹⁾
Type R [PtRh-Pt]	2019 = End Overdrive region (20190) -50...1769 = Nominal range (-500...17690) -170 = End Underdrive region (-1700)	0011b ¹⁾
Type S [PtRh-Pt]	2019 = End Overdrive region (20190) -50...1769 = Nominal range (-500...17690) -170 = End Underdrive region (-1700)	0100b ¹⁾
Type B [PtRh-PtRh]	2070 = End Overdrive region (20700) 0...1820 = Nominal range (0...18200) -120 = End Underdrive region (-1200)	0000b ¹⁾
Type C [WRe5-WRe26]	2500 = End Overdrive region (25000) 0...2315 = Nominal range (0...23150) -120 = End Underdrive region (-1200)	1010b ¹⁾

Measuring type Thermocouple:

compensation external (Measuring type coding: 1011b)

compensation internal (Measuring type coding: 1010b)

The evaluated thermo electromotive force is added to the force of the internal or external reference junction and is mapped to the 80mV measuring range.

Measuring range	Range / Representation	Range coding	
Type J [Fe-Cu-Ni IEC]		0101b	
Type K [Ni-Cr-Ni]		1000b	
... and so on (see above)		94.071mV = End Overdrive region (32511) - 80...80mV = Nominal range (-27648...27648) - 94.074mV = End Underdrive region (-32512)	.
Type C [WRe5-WRe26]		1010b ¹⁾	

¹⁾ The measuring range is available starting with firmware version V. 1.3.8. Since this measuring range is not supported by the Siemens SIMATIC manager, the parameterization only takes place exclusively at run time.

331-7Kx01 - AI 8(2)x12Bit - Diagnostics

Diagnostics


As soon as an error occurs, like "wire break" or "measuring value out of range", an entry is made in the diagnostic area that can be evaluated by means of the user application.

If you have released the diagnostic interrupts at the parameterization, incoming and outgoing error events are signaled by interrupts and monitored on the according analog input module via LED.

At a diagnostic interrupt the CPU interrupts the user application and works off the OB 82. For more detailed diagnostic information you may call the SFC 51 res. SFC 59 in the OB 82. The diagnostic data is consistent until you leave the OB 82.

Starting the diagnosis

When an error occurs and after error correction, the diagnosis is started. Via the parameterization you fix the diagnosis behavior at error:



A diagnostic interrupt is only transmitted to the CPU, if you activate the diagnostic interrupt in the parameterization window.

The following errors may initialize a diagnosis:

- Error in project engineering res. parameterization
- Wire break at current measuring
- Measuring range overflow
- Measuring range underflow
- Common mode error
- Lost process interrupt
- Failure of the external voltage supply

Error indication via measuring value and LEDs

Every analog input module sends, independent from the parameterization, the measuring value 7FFFh at overflow and 8000h at underflow when recognizing an error.

At activated *group diagnosis* the group diagnosis-LED (SF) and the error-LED that is assigned to that channel are blinking.

If you additionally activated the *wire break diagnosis* at current measuring, a wire break is shown via the error LED assigned to this channel.

Evaluating the diagnosis

At a diagnosis event the CPU interrupts the user program and branches into OB 82. This OB allows you via according programming to request detailed diagnostic information by means of the SFCs 51 and 59 and react to it.

After processing of the OB 82, the processing of the user application is continued. The diagnostic data are consistent until leaving the OB 82.

As soon as you have activated the diagnostic interrupt release, *record set 0* is transferred to the superordinated system in cause of an error. The *record set 0* has a fixed content and a length of 4byte. The content of *record set 0* may be monitored in plain text in the diagnosis window of the CPU.

For the extended diagnosis during run time, you may also evaluate the *record set 1* of 16byte length via SFCs 51 and 59.

Record set 0 and 1 have the following structure:

Diagnosis record set 0

Record set 0 (Byte 0 to 3):

Byte	Bit 7 ... Bit 0	Default
0	Bit 0: Error in module Bit 1: reserved Bit 2: External error Bit 3: Channel error Bit 4: external voltage supply missing Bit 6, 5: reserved Bit 7: Wrong parameters in module	00h
1	Bit 3 ... 0: Module class 0101 Analog module Bit 4: Channel information present Bit 7 ... 5: reserved	15h
2	reserved	00h
3	Bit 5 ... 0: reserved Bit 6: Process interrupt lost Bit 7: reserved	00h

**Diagnostics
record set 1**

Byte 0 to 15:

The record set 1 contains the 4byte of record set 0 and additionally 12byte module specific diagnostic data.

The diagnostic bytes have the following assignment:

Record set 1 (Byte 0 to 15):

Byte	Bit 7 ... Bit 0	Default
0 ... 3	Content record set 0 (see page before)	-
4	Bit 6 ... 0: Channel type 70h: Digital input 71h: Analog input 72h: Digital output 73h: Analog output 74h: Analog in-/output Bit 7: More channel types present 0: no 1: yes	71h
5	Bit 7 ... 0: Number of diagnostic bits, that the module throws per channel	08h
6	Bit 7 ... 0: Number of similar channels of a module	04h
7	Bit 0: Channel error Channel 0 ... Bit 7: Channel error Channel 7	00h
8	Bit 0: Project engineering/Parameterization error Channel 0 Bit 1: Common mode error Bit 3 ... 2: reserved Bit 4: Wire break Channel 0 Bit 5: reserved Bit 6: Underflow Channel 0 Bit 7: Overflow Channel 0	00h
...	...	
15	Bit 0: Project engineering/Parameterization error Channel 7 Bit 1: Common mode error Bit 3 ... 2: reserved Bit 4: Wire break Channel 7 Bit 5: reserved Bit 6: Underflow Channel 7 Bit 7: Overflow Channel 7	00h



Note!

Please note that the AI 2x12Bit (331-7KB01) exclusively supplies diagnostic data of the channel group 0/1!

Error cause and remedy

Message	Possible error cause	Remedial
Project engineering/ Parameterization error	Parameterization at run time: Wrong function code in record set	Proof the parameterization during run time
Wire break	Sensor allocation is too high-impedance	install another sensor type or cable with a higher cross-section
	Interruption of the conductor between module and sensor	Install conductor connection
	Channel is not wired (open)	Deactivate the channel group (parameter measuring type)
		Wire the channel
Measuring range underflow	Input value is under the underdrive region, error causes may be: <ul style="list-style-type: none"> • at measuring range 4 ... 20mA, 1 ... 5V <ul style="list-style-type: none"> - sensor connection polarity inversion - wrong measuring range • other measuring ranges <ul style="list-style-type: none"> - wrong measuring range 	Check connections Parameterize another measuring range Parameterize another measuring range
Measuring range overflow	Input value higher than overdrive region	Parameterize another measuring range
Process interrupt lost	During the processing of a process interrupt in OB40, a new process interrupt with the same error cause occurs.	
Failure of the external power supply	Connection of the external power supply forgotten	Supply the module with external DC 24V
	Power supply failure	Control external power supply and change it
	Cable defect res. not correctly connected	Control cable res. replace it
Common mode	Different potentials between grounds >3V or wire break at ground	Remove wire break, lower potential difference

Process interrupts

Process interrupts are limit value interrupts. They occur if they are released via parameterization and a measuring value is outside the defined range. Process interrupts may only be parameterized for the channels 0 and 2.

When a process interrupt occurs, the CPU interrupts the user application and processes the OB 40.


With the help of the OB 40 you may define, how your CPU should react at a process interrupt.

Initializing the process interrupt

As soon as a measuring value is out of the range defined in the parameterization, a process interrupt is initialized, if this option is released.

Via the parameterization you define the part of the nominal range, in which the value has to be, by means of defining high and low limit.

A process interrupt may only be initialized, when you have activated *hardware interrupt when limit exceeded*.



You may activate a process interrupt for channel 0 and 2. Using the default configuration, the process interrupts are not activated.

Reaction to a the process interrupt

At a process interrupt the CPU interrupts the user application and branches into the OB 40.

More detailed information about the channel, which limit value has been exceeded, are stored in the OB 40 in the variable OB 40_POINT_ADR in the local data double word 8 (LD 8).

The LD 8 has the following structure:

Byte	Bit 7... Bit 0
0	Bit:0 = 1: Upper limit value of channel 0 has been exceeded Bit:1 = 1: Upper limit value of channel 2 has been exceeded
1	Bit:0 = 1: Lower limit value of channel 0 has been exceeded Bit:1 = 1: Lower limit value of channel 2 has been exceeded
2 ... 3	reserved

Diagnostic message "Process interrupt lost"

If a second identical process interrupt occurs during processing interrupt in OB 40, the CPU branches into the OB 82 and activates the bit 6 in record set 0 of byte 3 for "process interrupt lost".

After having processed the OB 82, the CPU jumps back to OB 40.

Influence of the measuring values

The behavior of the analog input module depends on the location of the measuring value inside the value range.

The following table lists the different behaviors:

Measuring value is in	transmitted	SF-LED ⁴⁾	Diagnostics	Interrupt
Nominal range	meas. value	-	-	-
Over-/Underdrive region	meas. value	-	-	-
Overflow	7FFFh	ON ³⁾	Entry is set ³⁾	Diag. interrupt ¹⁾
Underflow	8000h	ON ³⁾	Entry is set ³⁾	Diag. interrupt ¹⁾
outside the parameterized limit value	meas. value	-	-	Process interrupt ²⁾

¹⁾ only if diagnostic interrupt is released in the parameterization.

²⁾ only if process interrupt is released in the parameterization.

³⁾ only if group diagnostics is released in the parameterization.

⁴⁾ independently from the chosen diagnostics, the group error LED is on when the external power supply is missing.

331-7Kx01 - AI 8x12Bit - Technical Data

331-7KF01

Order number	331-7KF01
Type	SM 331
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	95 mA
Power loss	3 W
Technical data analog inputs	
Number of inputs	8
Cable length, shielded	50 m
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	100 mA
Voltage inputs	✓
Min. input resistance (voltage range)	100 kΩ
Input voltage ranges	-80 mV ... +80 mV -250 mV ... +250 mV -500 mV ... +500 mV -1 V ... +1 V -2.5 V ... +2.5 V -5 V ... +5 V +1 V ... +5 V -10 V ... +10 V
Operational limit of voltage ranges	+/-0.6% ... +/-1.0%
Basic error limit voltage ranges with SFU	+/-0.4% ... +/-0.7%
Current inputs	✓
Min. input resistance (current range)	85 Ω
Input current ranges	-3.2 mA ... +3.2 mA -10 mA ... +10 mA -20 mA ... +20 mA 0 mA ... +20 mA +4 mA ... +20 mA
Operational limit of current ranges	+/-0.7%
Basic error limit current ranges with SFU	+/-0.5%
Resistance inputs	✓
Resistance ranges	0 ... 150 Ohm 0 ... 300 Ohm 0 ... 600 Ohm
Operational limit of resistor ranges	+/-0.7%
Basic error limit	+/-0.5%
Resistance thermometer inputs	✓
Resistance thermometer ranges	Pt100 Ni100
Operational limit of resistance thermometer ranges	+/-0.7% ... +/-0.8%
Basic error limit thermoresistor ranges	+/-0.5% ... +/-0.6%
Thermocouple inputs	✓
Thermocouple ranges	type J type R type K type N type L type E type T type S type B type C

Order number	331-7KF01
Operational limit of thermocouple ranges	+/-1.3% ... +/-2.0%
Basic error limit thermoelement ranges	+/-0.7% ... +/-1.0%
Programmable temperature compensation	✓
External temperature compensation	✓
Internal temperature compensation	✓
Resolution in bit	14
Measurement principle	Sigma-Delta
Basic conversion time	4ms...68ms / channel
Noise suppression for frequency	10 Hz/400 Hz
Initial data size	16 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	yes
Process alarm	yes, parameterizable
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	none
Group error display	red SF LED
Channel error display	red LED per channel
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-
Max. potential difference between inputs (Ucm)	DC 3 V
Max. potential difference between Mana and Mintern (Uiso)	DC 75 V/ AC 60 V
Max. potential difference between inputs and Mana (Ucm)	DC 3 V
Max. potential difference between inputs and Mintern (Uiso)	-
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	16
Output bytes	0
Parameter bytes	21
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	240 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

331-7KB01

Order number	331-7KB01
Type	SM 331
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	95 mA
Power loss	3 W
Technical data analog inputs	
Number of inputs	2
Cable length, shielded	50 m
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	100 mA
Voltage inputs	✓
Min. input resistance (voltage range)	100 kΩ
Input voltage ranges	-80 mV ... +80 mV -250 mV ... +250 mV -500 mV ... +500 mV -1 V ... +1 V -2.5 V ... +2.5 V -5 V ... +5 V +1 V ... +5 V -10 V ... +10 V
Operational limit of voltage ranges	+/-0.6% ... +/-1.0%
Basic error limit voltage ranges with SFU	+/-0.4% ... +/-0.7%
Current inputs	✓
Min. input resistance (current range)	85 Ω
Input current ranges	-3.2 mA ... +3.2 mA -10 mA ... +10 mA -20 mA ... +20 mA 0 mA ... +20 mA +4 mA ... +20 mA
Operational limit of current ranges	+/-0.7%
Basic error limit current ranges with SFU	+/-0.5%
Resistance inputs	✓
Resistance ranges	0 ... 150 Ohm 0 ... 300 Ohm 0 ... 600 Ohm
Operational limit of resistor ranges	+/-0.7%
Basic error limit	+/-0.5%
Resistance thermometer inputs	✓
Resistance thermometer ranges	Pt100 Ni100
Operational limit of resistance thermometer ranges	+/-0.7% ... +/-0.8%
Basic error limit thermoresistor ranges	+/-0.5% ... +/-0.6%
Thermocouple inputs	✓
Thermocouple ranges	type J type R type K type N type L type E type T type S type B type C
Operational limit of thermocouple ranges	+/-1.3% ... +/-2.0%
Basic error limit thermoelement ranges	+/-0.7% ... +/-1.0%
Programmable temperature compensation	✓
External temperature compensation	✓

Order number	331-7KB01
Internal temperature compensation	✓
Resolution in bit	14
Measurement principle	Sigma-Delta
Basic conversion time	4 ms/18 ms/22 ms/68 ms / channel
Noise suppression for frequency	10 Hz/400 Hz
Initial data size	4 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	yes
Process alarm	yes, parameterizable
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	none
Group error display	red SF LED
Channel error display	red LED per channel
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-
Max. potential difference between inputs (Ucm)	DC 3 V
Max. potential difference between Mana and Mintern (Uiso)	DC 75 V/ AC 60 V
Max. potential difference between inputs and Mana (Ucm)	DC 3 V
Max. potential difference between inputs and Mintern (Uiso)	-
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	4
Output bytes	0
Parameter bytes	21
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	220 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

**Additional
Technical data**

Order number	VIPA 331-7KF01	VIPA 331-7KB01																																																																
Data for specific module																																																																		
Number of inputs for 4wire resistance-type sensor	4	1																																																																
Voltages, Currents, Potentials																																																																		
Power supply of the transmitters - Supply voltage - Supply current - Short-circuit-proof	13V at 30mA max. 30mA (per channel) yes																																																																	
Constant current for resistance-type sensor	2.25mA																																																																	
Analog value generation																																																																		
Integration - /conversion time/resolution (per channel) - programmable - Conversion rate in Hz - Integration time in ms - Basic conversion time in ms Additional conversion time for open circuit monitoring in ms - Resolution (incl. overrange) in Bit - Noise suppression for frequency f1 in Hz - Basic execution time of the module in ms (all channels enabled)	<table border="1"> <thead> <tr> <th colspan="4"></th> <th colspan="4">yes</th> </tr> <tr> <th>400</th> <th>60</th> <th>50</th> <th>10</th> <th>400</th> <th>60</th> <th>50</th> <th>10</th> </tr> </thead> <tbody> <tr> <td>2.5</td> <td>16²/₃</td> <td>20</td> <td>100</td> <td>2.5</td> <td>16²/₃</td> <td>20</td> <td>100</td> </tr> <tr> <td>4</td> <td>18</td> <td>22</td> <td>68</td> <td>4</td> <td>18</td> <td>22</td> <td>68</td> </tr> <tr> <td colspan="4"></td> <td colspan="4">4ms</td> </tr> <tr> <td>9</td> <td>12</td> <td>12</td> <td>14</td> <td>9</td> <td>12</td> <td>12</td> <td>14</td> </tr> <tr> <td>-</td> <td>-</td> <td>-</td> <td>50/ 60</td> <td>-</td> <td>-</td> <td>-</td> <td>50/ 60</td> </tr> <tr> <td>42</td> <td>154</td> <td>186</td> <td>554</td> <td>18</td> <td>46</td> <td>54</td> <td>146</td> </tr> </tbody> </table>						yes				400	60	50	10	400	60	50	10	2.5	16 ² / ₃	20	100	2.5	16 ² / ₃	20	100	4	18	22	68	4	18	22	68					4ms				9	12	12	14	9	12	12	14	-	-	-	50/ 60	-	-	-	50/ 60	42	154	186	554	18	46	54	146
				yes																																																														
400	60	50	10	400	60	50	10																																																											
2.5	16 ² / ₃	20	100	2.5	16 ² / ₃	20	100																																																											
4	18	22	68	4	18	22	68																																																											
				4ms																																																														
9	12	12	14	9	12	12	14																																																											
-	-	-	50/ 60	-	-	-	50/ 60																																																											
42	154	186	554	18	46	54	146																																																											
Smoothing of the measured values	none																																																																	
Suppression of interference, limits error																																																																		
Noises suppression for f=n x (f1 ±1%) (f1=interference frequency, n=1,2,...) - Common-mode interference (U _{CM} < 3V) - Series-mode noise (peak value of noise < nominal value of input range)	> 70dB > 40dB																																																																	
Crosstalk between the inputs	> 50dB																																																																	
Temperature error (with reference to the input range)	±0.005%/K																																																																	
Linearity error (with reference to the input range)	±0.02%																																																																	
Repeatability (in steady state at 25°C, with reference to the input range)	±0.05%																																																																	
Temperature error of internal compensation	±1.5%																																																																	
Data for selecting a sensor																																																																		
- Voltage	Input range ± 80mV, ± 250mV ± 500mV, ± 1V ± 2.5V, ± 5V 1 ... 5V, ± 10V	Input resistance 10MΩ 10MΩ 100kΩ 100kΩ																																																																
- Current	± 3.2mA, ± 10mA, ± 20mA 0 ... 20mA, 4 ... 20mA	85Ω 85Ω																																																																
- Resistors	0 ... 150Ω, 300Ω, 600Ω	10MΩ																																																																
- Resistance thermometer	Pt100, NI100	10MΩ																																																																
- Thermocouples	Type J, K, N, L, E, T, S, B, C, R	10MΩ																																																																
Maximum input voltage for voltage input (destruction limit)	max. 20V																																																																	
Maximum input current for current input (destruction limit)	max. 40mA																																																																	

Order number	VIPA 331-7KF01	VIPA 331-7KB01
Data for selecting a sensor		
Connection of the sensors - for measuring voltage - for measuring current as 2wire transmitter as 4wire transmitter - for measuring resistance with 2conductor connection with 3conductor connection with 4conductor connection	possible	possible
Characteristic linearization - for RTD - for thermocouples	Pt100, NI 100 Standard / Climate Type E, N, J, K, L, T, S, B, C, R Ni100 Standard / Climate	
Temperature compensation - internal temperature compensation - external temperature compensation with compensating box - Compensation for 0°C comparison point temperature	parameterizable	possible
Technical unit for temperature measurement	°C	

Thermocouple for high temperature measurement

The thermocouples for high temperature measurement (Type S, B, C, R) produce physically caused smaller thermo electromotive forces than the "normal" thermocouples (Type E, N, J, K, L).

In the following table there is a comparison between the thermo electromotive forces of the thermocouple of the type N to type S, B, C, R.

Thermo electromotive forces of Thermocouples	0°C	500°C	1000°C	1700°C
Type N in $\mu\text{V} / ^\circ\text{C}$	26	38	39	not possible
Type S in $\mu\text{V} / ^\circ\text{C}$	5	10	12	12
Type B in $\mu\text{V} / ^\circ\text{C}$	0	5	9	11
Type C in $\mu\text{V} / ^\circ\text{C}$	13	19	18	14
Type R in $\mu\text{V} / ^\circ\text{C}$	5	11	13	13

Chapter 3 Analog Output Modules

Overview This chapter contains a description of the structure and the operation of the VIPA analog output modules.

Content	Topic	Page
	Chapter 3 Analog Output Modules	3-1
	General	3-2
	Connecting loads and actuators	3-3
	Analog value representation	3-4
	Parameterization - Basics.....	3-5
	Diagnostics.....	3-8
	332-5HB01 - AO 2/4x12Bit U/I 2-channel	3-12
	332-5HD01 - AO 2/4x12Bit U/I 4-channel.....	3-16
	332-5HD50 - AO 4x12Bit I for manual operation.....	3-20
	332-5HD60 - AO 4x12Bit U for manual operation	3-25

General

Cables for analog signals

For analog signals you should use isolated cables to reduce interference. The cable screening should be grounded at both ends. If there are differences in the potential between the cable ends, there may occur a potential compensating current that could disturb the analog signals. In this case you should ground the cable screening only at one end.

Connecting loads and actuators

Depending on the module the following actuators may be connected:

- Current input: $\pm 20\text{mA}$, 4 ... 20mA, 0 ... 20mA
- Voltage input: $\pm 10\text{V}$, 1 ... 5V, 0 ... 10V



Note!

Please take always care of the correct polarity when connecting actuators! Please leave the output pins of not used channels disconnected and configure the *output type* of the channel to "deactivated".

Parameterization

The modules can be configured by means of a hardware configuration or rather during run time by SFCs.

In not parameterized status, the modules with order number 332-5Hx01 are set to voltage output " $\pm 10\text{V}$ ". The interrupt output of every module is deactivated.

Diagnostic functions

Every module described here has diagnostic functions. Depending on the module the following errors may initialize a diagnostic message:

A diagnostic interrupt is only transmitted to the CPU, if you have activated the diagnostic interrupt in the parameterization window.

The following errors a diagnosis:

- Wire break at current output (only 332-5Hx01)
- Ground short circuit (only 332-5Hx01)
- Operate the front switch (only 332-5HDx0)
- Failure of the external voltage supply
- Project engineering and parameterization error

For more detailed diagnostic information you may call the SFCs 51 and 59 during run time. You can request detailed diagnostic information and react on it by means of the SFCs.


Output pulse at Power ON/OFF and at output range alterations during run time

System-dependently at switching on/off the power supply and at output range alterations during run time, there may arise wrong values for app. 10ms.

Connecting loads and actuators

Connecting loads at current output

Loads at the current output have to be connected at Q_x and associated ground M_x of the analog circuit. Please always pay attention to correct polarity.




Connecting loads at voltage output at 4-wire cabling (only 332-5Hx01)

The connection of a load at a voltage output can take place both in 2- and in 4-wire cabling. Please note with the modules 332-5HDx0 the 4-wire cabling is not possible.


With 4-wire cabling you achieve a high exactness at the load. The sensor lines $S+_x$ and $S-_x$ are directly connected to the load. Thus, the voltage may be measured and adjusted directly at the load.

Interference or voltage losses may cause potential differences between $S-_x$ and M_x . These should not exceed the permissible value of DC 3V, because this may disturb the accuracy of the analog signal.



Connecting loads at voltage output at 2-wire cabling

Connect the load at pin QV_x and the point of reference of the measuring circle M_x (x = No. of the channel).



Analog value representation

Analog value representation

The analog values are only processed by the CPU in binary representation. Hereby the process signals are transformed into digital format in the analog module and passed on to the CPU as word variable.

The digitized analog value is the same for input and output values at the same nominal range.

The resolution depends on the used module as follows:

		Analog value															
		High byte								Low byte							
Bit number		15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Resolution	SG	Analog value (word)															
12bit + Sign	SG	Relevant output value												X	X	X	
11bit + Sign	SG	Relevant output value												X	X	X	X
10bit + Sign	SG	Relevant output value											X	X	X	X	X

* The least significant irrelevant bits of the output value are marked by "X".

Sign bit (SG)

The algebraic sign bit is represented by Bit 15. Here it is essential:

Bit 15 = "0" → positive value

Bit 15 = "1" → negative value

Parameterization - Basics

Overview

There are the following possibilities for parameterization:

- Parameterization by hardware configuration of Siemens SIMATIC manager or with WinPLC7 from VIPA.
- Parameterization during run time by means of SFCs.

Parameterization by hardware configuration

To be compatible to the Siemens SIMATIC manager the following steps are to be accomplished:

- Start the hardware configurator from Siemens
- Create a new project
- Configure your CPU.
- Link-up your System 300V modules in the plugged-in sequence starting with slot 4. Here the analog output modules of VIPA are to be projected as analog output modules of Siemens in accordance with the following rules:

VIPA 332-5HD01 to be configured as **6ES7 332-5HD01-0AB0**
VIPA 332-5HDx0

VIPA 332-5HB01 to be configured as **6ES7 332-5HB01-0AB0**

The analog output modules can be found at the hardware catalog at *Simatic 300 > SM-300*.

- If needed parameterize the CPU respectively the modules. The parameter window appears as soon as you double click on the according module. At this window the according parameter can be changed.
- Save your project, switch the CPU to STOP and transfer your project to the CPU. As soon as the CPU is switched to RUN the parameters are transferred to the connected modules.

Parameters

The following parameters can be adjusted at the analog output modules:

- Starting address of the output data
- Output type and behavior
- Reaction at CPU-STOP
- Diagnostics and interrupt reaction

A closer description of the parameters can be found at the following pages.

Parameterization during run time by means of SFCs

If the module gets parameters, which are not supported by the module, for example a current module is to be configured as a voltage module, these parameters are interpreted as wrong parameters and an error is initialized. At the parameterization, 16byte long parameter area is set in the record sets 0 and 1. Deploying the SFCs 55, 56 and 57, you may alter parameters during run time and transfer them to the module. The following tables show the structure of the parameters in record set 0 and 1:

Parameters Record set 0
(not parameterizable via SFC)

Record set 0 (Byte 0 to 1):

Byte	Bit 7 ... Bit 0	Default
0	Sum diagnosis bit coded Bit 0: Channel 0 Bit 1: Channel 1 Bit 2: Channel 2 Bit 3: Channel 3 Bit 7 ... 4: reserved	00h
1	reserved	00h

Parameters Record set 1

Record set 1 (Byte 0 to 13):

Byte	Bit 7 ... Bit 0	Default		
		332-5Hx01	332-5HD50	332-5HD60
0	Bit 5 ... 0: reserved Bit 6: Diagnostic interrupt release Bit 7: reserved	00h	00h	00h
1	Reaction at CPU-STOP Bit 0: Channel 0 Bit 1: Channel 1 Bit 2: Channel 2 Bit 3: Channel 3	00h	00h	00h
2	Mode Channel 0 Bit 3 ... 0: Output range Bit 7 ... 4: Output type	19h (+/-10V)	23h (4...20mA)	18h (0...10V)
3	Mode Channel 1 Bit 3 ... 0: Output range Bit 4 ... 7: Output type	19h (+/-10V)	23h (4...20mA)	18h (0...10V)
4	Mode Channel 2 Bit 3 ... 0: Output range Bit 7 ... 4: Output type	19h (+/-10V)	23h (4...20mA)	18h (0...10V)
5	Mode Channel 3 Bit 3 ... 0: Output range Bit 7 ... 4: Output type	19h (+/-10V)	23h (4...20mA)	18h (0...10V)
6, 7	Replacement value Channel 0	0000h	0000h	0000h
8, 9	Replacement value Channel 1	0000h	0000h	0000h
10, 11	Replacement value Channel 2	0000h	0000h	0000h
12, 13	Replacement value Channel 3	0000h	0000h	0000h

The according coding of output type and output range can be found at the following page!




Note!

With setting the mode parameter to 00h the according channel is deactivated. To switch at not symmetric output range the current respectively the voltage output to 0 value at CPU STOP, the following replacement values should be used:

- output range 1...5V: 0V ↔ -6912dez = E500h
- output range 4...20mA: 0mA ↔ -6912dez = E500h

- Release diagnostic interrupt Please regard as soon as you release the diagnostic interrupt at run time, the according group diagnostics are just activated during hardware configuration. Otherwise no interrupt can be initialized.
More information can be found at "Diagnostics" further down.
- CPU-Stop reaction Here the module reaction at CPU-STOP can be set. You have the following possibilities:
- 0CV: output de-energized (according to the module)
 - KLV: Keep last value
 - SV: Substitute a value
- Get mode output type output range Depending on the module at the register "Outputs" at *Output* the type voltage, current output or deactivated and the according range can be selected.
As shown in the following illustration the parameter *mode* is made up of the coding of the output range and type during run time parameterization each channel.



The corresponding codes can be found in the following table. Within the output types the output ranges are specified, for which a binary output range code is to be specified in each case.

Output type voltage output (Output type coding: 0001b)

Output range	Range / Unit	Output range coding
0...10V	11.758V = End overdrive region (32511) 0...10V = Nominal region (0...27648)	1000b
1...5V	5.879V = End overdrive region (32511) 1...5V = Nominal range (0...27648) 0V = End underdrive region (-6912)	0111b
+/- 10V	11.758V = End overdrive region (32511) -10...10V = Nominal range (-27648...27648) -11.759V = End underdrive region (-32512)	1001b

Output type current output (Output type coding: 0010b)

Output range	Range / Unit	Output range coding
0...20mA	23.515mA = End overdrive region (32511) 0...20mA = Nominal range (0...27648)	0010b
4...20mA	22.810mA = End overdrive region (32511) 4...20mA = Nominal range (0...27648) 0mA = End underdrive region (-6912)	0011b
+/- 20mA	23.515mA = End overdrive region (32511) -20...20mA = Nominal range (-27648...27648) -23.515mA = End underdrive region (-32512)	0100b

Diagnostics


Overview

As soon as an error occurs and activated *Group diagnostics*, it is record in the diagnostic area that can be evaluated by means of the user application. If the diagnostic interrupt is released at the parameterization, incoming and outgoing error events are signaled by interrupts and monitored on the according analog output module via LED.

At a diagnostic interrupt the CPU interrupts its user application and works on the OB 82. For more detailed diagnostic information you may call the SFC 51 res. SFC 59 in the OB 82. The diagnostic data is consistent until you leave the OB 82.

Starting the diagnosis

When an error occurs and after error correction, the diagnosis is started. Via the parameterization you fix the diagnosis behavior at error:



A diagnostic interrupt is only transmitted to the CPU, if you have activated the diagnostic interrupt in the parameterization window.

The following errors a diagnosis:

- Wire break at current output (only 332-5Hx01)
- Ground short circuit (only 332-5Hx01)
- Operate the front switch (only 332-5HDx0)
- Failure of the external voltage supply
- Project engineering and parameterization error

Diagnostics data The diagnostics data is stored in the record sets 0 and 1 of the system data area.
 As soon as you have activated the diagnostic interrupt release of the parameter area (record set 1, byte 0), on error *record set 0* of the diagnostics data is transferred to the superordinated system.
 For extended diagnosis during run time, you may also evaluate the *Record set 1* via the SFCs 51 and 59.

Evaluate diagnosis At a diagnostics event the CPU interrupts the user program and branches into OB 82. This OB allows you via according programming to request detailed diagnostic information by means of the SFCs 51 and 59 and react to it.
 After the working off of the OB 82, the processing of the user application is continued. The diagnostic data are consistent until leaving the OB 82.

Diagnosis Record set 0 The *record set 0* has a fixed content. The content of *record set 0* may be monitored in plain text in the diagnosis window of the CPU.

Byte	Bit 7 ... Bit 0	Default
0	Bit 0: Error in module Bit 1: reserved Bit 2: External error Bit 3: Channel error Bit 4: external voltage supply missing Bit 5, 6: reserved Bit 7: Wrong parameter in module	00h
1	Bit 3 ... 0: Module class 0101 Analog module Bit 4: Channel information present	15h
2	Bit 0, 1 reserved Bit 2: Operating status 0: RUN 1: STOP Bit 7 ... 4: reserved	00h
3	not used	00h

Diagnosis The record set 1 contains the 4byte of record set 0 and additionally 8byte
Record set 1 module specific diagnostic data.

The diagnostic bytes have the following content:

Byte	Bit 7 ... Bit 0	Default	
0 ... 3	Content record set 0 (see page before)		
4	Bit 6 ...0: Channel type: 73h: Analog output Bit 7: More channel types present 0: no 1: yes	73h	
5	Bit 7 ... 0: Number of diagnostic bits, that the module throws per channel	08h	
6	Bit 7 ... 0: Number of similar channels of a module	04h	
7	Bit 0: Channel error Channel 0 Bit 1: Channel error Channel 1 Bit 2: Channel error Channel 2 Bit 3: Channel error Channel 3 Bit 4: Channel error Channel 4 Bit 7 ... 5: reserved	00h	
	332-5Hx01	332-5HDx0	
8	Channel specific error: Channel 0 Bit 0: Project engineering/ Parameterization error Bit 1, 2: reserved Bit 3: Short circuit after M Bit 4: Wire break Bit 7...5: reserved	Channel specific error: Channel 0 Bit 0: Project engineering/ Parameterization error Bit 4...1: reserved Bit 5: Front switch 0: Automatic 1: Hand operation Bit 7...6: reserved	00h
9	Channel specific error: Channel 1 Content see Channel 0	Channel specific error: Channel 1 Content see Channel 0	00h
...			
11	Channel specific error: Channel 3 Content see Channel 0	Channel specific error: Channel 3 Content see Channel 0	00h
12 ... 15	reserved		

Channel error by
switching to manual
operation at
332-5HDx0

The switch to *manual operation* is interpreted as a channel error. The appropriate bit for channel errors in byte 7 of record set 1 is set.
An Interrupt_{going} is only possible if all by group diagnostics activated switches are turned to automatic operation.

Error indication via LEDs (only 332-5Hx01)

At activated *group diagnostics* the group error LED (SF) and the according channel error LED are activated by diagnostic requirement of the modules with order no. 332-5Hx01.

Evaluating the diagnosis

At a diagnostic requirement the CPU interrupts the user program and branches into OB 82. This OB allows you via according programming to request detailed diagnostic information by means of the SFCs 51 and 59 and react to it.

After the working off of the OB 82, the processing of the user application is continued. The diagnostic data are consistent until leaving the OB 82.

Error cause and remedy

Message	Possible error cause	Remedial
External load voltage missing	Load voltage L+ of the module is missing	Proof connections L+ and M, Proof power supply
Project engineering/Parameterization error	Wrong parameters have been transferred to the module	Proof parameterization
Ground short circuit (only 332-5Hx01)	Output overload Short circuit of the output QV after M-	Remove overload Check load connection for short circuit
Wire break (only 332-5Hx01)	Line interruption between module and actuator actuator is too high-resistance Channel is not used	Check line Use another actuator type Use lines with more core-cross section Deactivate channel in parameterization
Front switch manual mode (only 332-5HDx0)	Manual intervention by means of the front switch.	switch all by group diagnostics activated switches to <i>automatic operation</i> .

332-5HB01 - AO 2/4x12Bit U/I 2-channel


Order data	AO 2x12Bit	VIPA 332-5HB01
Description	There are 2 analog outputs which functions may be parameterized individually. The module has to be provided with external DC 24V.	
Properties	<ul style="list-style-type: none"> • 2 individual parameterizable outputs • the outputs are parameterizable per channel as <ul style="list-style-type: none"> - voltage output - current output - deactivated • usable for actuators with inputs of $\pm 10V$, 1 ... 5V, 0 ... 10V, $\pm 20mA$, 4 ... 20mA or 0 ... 20mA • parameterizable diagnostics and diagnostics interrupt • isolated between backplane bus and load voltage 	
Parameterization	After Power ON, the module has the following default settings: <ul style="list-style-type: none"> • Output range: $\pm 10V$ for all channels • Interrupts are deactivated The module is to be projected as Siemens analog output module 6ES7 332-5HB01-0AB0 .	




Note!

The deployment of the module at the active backplane bus is not possible!

Structure



**Pin assignment
Status monitor**



Note!

Please regard, that you must not connect the S-Pin at current output!



Attention!

Please regard that the modules do not have hardware precautions against wrong parameterization. The setting of the according measuring range is exclusively at the project engineering.

**Status monitor
via LEDs**

LED	Description
SF	Group error: On at parameterized group diagnostics, as soon as a diagnostic entry is present. On independently from diagnostics at missing external voltage supply
Q0...Q1	Channel active On when the according output channel has been activated
F0...F1	Channel error On together with SF at the according channel with error.

Technical data

Order number	332-5HB01
Type	SM 332
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	100 mA
Power loss	2.5 W
Technical data analog outputs	
Number of outputs	2
Cable length, shielded	-
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	70 mA
Voltage output short-circuit protection	✓
Voltage outputs	✓
Min. load resistance (voltage range)	1 kΩ
Max. capacitive load (current range)	1 μF
Output voltage ranges	-10 V ... +10 V 0 V ... +10 V +1 V ... +5 V
Operational limit of voltage ranges	+/-0.2% ... +/-0.8%
Basic error limit voltage ranges with SFU	+/-0.1% ... +/-0.5%
Current outputs	✓
Max. in load resistance (current range)	500 Ω
Max. inductive load (current range)	10 mH
Output current ranges	-20 mA ... +20 mA 0 mA ... +20 mA +4 mA ... +20 mA
Operational limit of current ranges	+/-0.3% ... +/-0.8%
Basic error limit current ranges with SFU	+/-0.2% ... +/-0.5%
Settling time for ohmic load	0.2 ms
Settling time for capacitive load	1 ms
Settling time for inductive load	1 ms
Resolution in bit	13
Conversion time	0.5 ms all channels
Substitute value can be applied	yes
Output data size	4 Byte
Status information, alarms, diagnostics	
Status display	green LED per channel
Interrupts	yes
Process alarm	no
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	none
Group error display	red SF LED
Channel error display	red LED per channel
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-
Max. potential difference between inputs (Ucm)	-
Max. potential difference between Mana and Mintern (Uiso)	DC 75 V/ AC 60 V
Max. potential difference between inputs and Mana (Ucm)	-
Max. potential difference between inputs and	-

Order number	332-5HB01
Mintern (Uiso)	
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	0
Output bytes	4
Parameter bytes	21
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	230 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

The error limits were determined with a load $R=1G\Omega$.

At voltage output the resistance of output of the module amounts 30 Ω .

The error limits were determined with a load $R=10\Omega$.

Additional Technical Data

Order number	VIPA 332-5HB01
Analog value generation	
Resolution (incl. sign) ±10V; ±20mA 1 ... 5V; 4 ... 20mA 0 ... 10V; 0 ... 20mA	12Bit + sign 11Bit 12Bit
Cycle time (all channels)	0.5ms
Suppression of interference, Limits of Error	
Crosstalk between outputs	> 40dB
Temperature error (with reference to the output range)	±0.01%/K
Linearity error (with reference to the output range)	±0.1%
Repeatability (in steady state at 25°C, referred to output range)	±0.05%
Output ripple; Range 0 to 50kHz (referred to output range)	±0.05%

332-5HD01 - AO 2/4x12Bit U/I 4-channel


Order data	AO 4x12Bit	VIPA 332-5HD01
Description	There are 4 analog outputs which functions may be parameterized individually. The module has to be provided with external DC 24V.	
Properties	<ul style="list-style-type: none"> • 4 individual parameterizable outputs • the outputs are parameterizable per channel as <ul style="list-style-type: none"> - voltage output - current output - deactivated • usable for actuators with inputs of $\pm 10V$, 1 ... 5V, 0 ... 10V, $\pm 20mA$, 4 ... 20mA or 0 ... 20mA • parameterizable diagnostics and diagnostics interrupt • isolated between backplane bus and load voltage 	
Parameterization	After Power ON, the module has the following default settings: <ul style="list-style-type: none"> • Output range: $\pm 10V$ for all channels • Interrupts are deactivated The module is to be projected as Siemens analog output module 6ES7 332-5HD01-0AB0 .	




Note!

The deployment of the module at the active backplane bus is not possible!

Structure



**Pin assignment
Status monitor**



Note!

Please regard, that you must not connect the S-Pin at current output!

Attention!

Please regard that the modules do not have hardware precautions against wrong parameterization. The setting of the according measuring range is exclusively at the project engineering.

**Status monitor
via LEDs**

LED	Description
SF	Group error: On at parameterized group diagnostics, as soon as a diagnostic entry is present. On independently from diagnostics at missing external voltage supply
Q0...Q3	Channel active On when the according output channel has been activated
F0...F3	Channel error On together with SF at the according channel with error.

Technical data

Order number	332-5HD01
Type	SM 332
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	125 mA
Power loss	3.5 W
Technical data analog outputs	
Number of outputs	4
Cable length, shielded	-
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	115 mA
Voltage output short-circuit protection	✓
Voltage outputs	✓
Min. load resistance (voltage range)	1 kΩ
Max. capacitive load (current range)	1 μF
Output voltage ranges	-10 V ... +10 V 0 V ... +10 V +1 V ... +5 V
Operational limit of voltage ranges	+/-0.2% ... +/-0.8%
Basic error limit voltage ranges with SFU	+/-0.1% ... +/-0.5%
Current outputs	✓
Max. in load resistance (current range)	500 Ω
Max. inductive load (current range)	10 mH
Output current ranges	-20 mA ... +20 mA 0 mA ... +20 mA +4 mA ... +20 mA
Operational limit of current ranges	+/-0.3% ... +/-0.8%
Basic error limit current ranges with SFU	+/-0.2% ... +/-0.5%
Settling time for ohmic load	0.2 ms
Settling time for capacitive load	1 ms
Settling time for inductive load	1 ms
Resolution in bit	13
Conversion time	1 ms all channels
Substitute value can be applied	yes
Output data size	8 Byte
Status information, alarms, diagnostics	
Status display	green LED per channel
Interrupts	yes
Process alarm	no
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	none
Group error display	red SF LED
Channel error display	red LED per channel
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-
Max. potential difference between inputs (Ucm)	-
Max. potential difference between Mana and Mintern (Uiso)	DC 75 V/ AC 60 V
Max. potential difference between inputs and Mana (Ucm)	-
Max. potential difference between inputs and	-

Order number	332-5HD01
Mintern (Uiso)	
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	0
Output bytes	8
Parameter bytes	21
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	230 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

Additional Technical Data

Order number	VIPA 332-5HD01
Analog value generation	
Resolution (incl. sign) ±10V; ±20mA 1 ... 5V; 4 ... 20mA 0 ... 10V; 0 ... 20mA	12Bit + sign 11Bit 12Bit
Cycle time (all channels)	1ms
Suppression of interference, Limits of Error	
Crosstalk between outputs	> 40dB
Temperature error (with reference to the output range)	±0.01%/K
Linearity error (with reference to the output range)	±0.1%
Repeatability (in steady state at 25°C, referred to output range)	±0.05%
Output ripple; Range 0 to 50kHz (referred to output range)	±0.05%

332-5HD50 - AO 4x12Bit I for manual operation


Order data AO 4x12Bit I for manual operation VIPA 332-5HD50

Description For each channel there is a 2-pole switch with associated potentiometer on the front side of the two modules. An analog value may be preset by the potentiometer, which is issued at the corresponding channel by switching to manual operation.
The module has to be provided with external DC 24V.

- Properties**
- 4 individual parameterizable outputs
 - the outputs are parameterizable per channel as:
 - Current output 4...20mA
 - deactivated
 - usable for actuators with an input of 4 ... 20mA
 - parameterizable diagnostics and diagnostics interrupt
 - 1 switch each channel (Automatic-/Manual operation)
 - 1 potentiometer each channel
 - isolated between backplane bus and load voltage
 - status LED for power supply

Parameterization After Power ON the interrupts are deactivated.
The modules have are to be configured as 6ES7 332-5HD01 from Siemens. More information can be found at chapter "Parameterization - Basics" above.


Structure



Pin assignment
Status monitor

Pin	Circuit diagram	LED	Description
1	1 L+ DC 24V	L+	LED (green) supply voltage is on
2	2		
3	3 Q ₀	H A	
4	4		
5	5		
6	6 M ₀		
7	7 Q ₁	H A	
8	8		
9	9		
10	10 M ₁		
11		SM332	
12	12 Q ₂	H A	
13	13		
14	14 M ₂		
15	15 Q ₃	H A	
16	16		
17	17		
18	18 M ₃		
19	19		
20	20 M		

Schematic diagram





Manual operation

For each channel there is a 2-pole switch with associated potentiometer on the front side.

The operating mode automatic or manual may be toggled by the switch.

At *manual operation* the module issues the value at the according channel adjusted by the potentiometer.

Depending on the switch position there is the following action:

Front switch	Description
<p>Manual operation</p> 	<p>Issues at the output channel the value adjusted by the potentiometer.</p> <p>Note! As long as the module is supplied with DC24V, in manual operation, independently of the mode of operation of the CPU, the by potentiometer adjusted value is issued at the output channel.</p>
<p>Automatic operation</p> 	<p>The channel operates as a "normal" analog output channel and can be controlled by PLC program.</p>

Potentiometer

For each channel there is a potentiometer on the front side. Here you can preset an analog value from min. up to max. of the nominal range.

If the potentiometer is turned in the clockwise direction beyond the *max.* position, then the overdrive region is reached. Hardware conditionally an exact marking of the ranges is not possible.

As soon as you turn the switch into position "H" (manual operation), the value adjusted by the potentiometer is issued at the according output channel.

Depending on the module there are the following ranges:



Order no.	Nominal range (min. ... max.)	max. overdrive region
VIPA 332-5HD50	4...20mA	ca. 24mA
VIPA 332-5HD60	0...10V	ca. 12V

Channel error by switching to manual operation

The switch to *manual operation* is interpreted as a channel error. The appropriate bit for channel errors in byte 7 of the diagnostics record set 1 is set.

An Interrupt_{going} is only possible if all by group diagnostics activated switches are turned to automatic operation.

More can be found in the chapter "Diagnostics" above.



Danger!

With the modules you can cause a jump in the analog value by means of the switch, independently of the CPU operation mode, as long as the module is power supplied. This could lead to material damage or personal injury!

Please regard also that disconnecting res. connecting during operation, the so-called "Hot Swapping", is not possible!

Technische Daten

Order number	332-5HD50
Type	SM 332
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	80 mA
Power loss	3.5 W
Technical data analog outputs	
Number of outputs	4
Cable length, shielded	-
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	130 mA
Voltage output short-circuit protection	-
Voltage outputs	-
Min. load resistance (voltage range)	-
Max. capacitive load (current range)	-
Output voltage ranges	-
Operational limit of voltage ranges	-
Basic error limit voltage ranges	-
Current outputs	✓
Max. in load resistance (current range)	500 Ω
Max. inductive load (current range)	10 mH
Output current ranges	+4 mA ... +20 mA
Operational limit of current ranges	+/-0.4%
Basic error limit current ranges	+/-0.2%
Settling time for ohmic load	0.5 ms
Settling time for capacitive load	-
Settling time for inductive load	0.5 ms
Resolution in bit	12
Conversion time	0,5 ms all channels
Substitute value can be applied	yes
Output data size	8 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	-
Process alarm	no
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	green LED
Group error display	none
Channel error display	none
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-
Max. potential difference between inputs (U _{cm})	-
Max. potential difference between Mana and Mintern (U _{iso})	DC 75 V/ AC 60 V
Max. potential difference between inputs and Mana (U _{cm})	-
Max. potential difference between inputs and Mintern (U _{iso})	-
Max. potential difference between Mintern and outputs	-

Order number	332-5HD50
Insulation tested with	DC 500 V
Datasizes	
Input bytes	0
Output bytes	8
Parameter bytes	21
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	250 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	-

The error limits were determined with a load $R=10\Omega$.

Additional Technical Data

Artikelnummer	VIPA 332-5HD50
Suppression of interference, Limits of error	
Crosstalk between the outputs	> 40dB
Temperature error (with reference to the output range)	$\pm 0.01\%/K$
Linearity error (with reference to the input range)	$\pm 0.15\%$
Repeatability (in steady state at 25°C, referred to output range)	$\pm 0.05\%$
Output ripple; range 0 to 50kHz (referred to output range)	$\pm 0.05\%$
Data for selecting an actuator	
Current outputs - No-load voltage	15V
Destruction limit against voltage/currents applied from outside - Voltage at outputs to M_{ANA} - Current	max. 15V max. 25mA
Connecting actuators - 2-conductor connection	possible

332-5HD60 - AO 4x12Bit U for manual operation


Order data AO 4x12Bit U for manual operation VIPA 332-5HD60

Description For each channel there is a 2-pole switch with associated potentiometer on the front side of the two modules. An analog value may be preset by the potentiometer, which is issued at the corresponding channel by switching to manual operation.
The module has to be provided with external DC 24V.

- Properties**
- 4 individual parameterizable outputs
 - the outputs are parameterizable per channel as:
 - voltage output 0...10V
 - deactivated
 - usable for actuators with an input of 0 ... 10V
 - parameterizable diagnostics and diagnostics interrupt
 - 1 switch each channel (Automatic-/Manual operation)
 - 1 potentiometer each channel
 - isolated between backplane bus and load voltage
 - status LED for power supply

Parameterization After Power ON the interrupts are deactivated.
The module has to be configured as 6ES7 332-5HD01 from Siemens. More information can be found at chapter "Parameterization - Basics" above.


Structure



Pin assignment
Status monitor

Pin	Circuit diagram	LED	Description
1	1 L+ DC 24V	L+	LED (green) supply voltage is on
2	2		
3	3 Q ₀	H A	
4	4		
5	5		
6	6 M ₀		
7	7 Q ₁	H A	
8	8		
9	9		
10	10 M ₁		
11	11		
12	12 Q ₂	H A	
13	13		
14	14 M ₂		
15	15 Q ₃	H A	
16	16		
17	17		
18	18 M ₃		
19	19		
20	20 M		

Schematic diagram





Manual operation

For each channel there is a 2-pole switch with associated potentiometer on the front side.

The operating mode automatic or manual may be toggled by the switch.

At *manual operation* the module issues the value at the according channel adjusted by the potentiometer.

Depending on the switch position there is the following action:

Front switch	Description
<p>Manual operation</p> 	<p>Issues at the output channel the value adjusted by the potentiometer.</p> <p>Note! As long as the module is supplied with DC24V, in manual operation, independently of the mode of operation of the CPU, the by potentiometer adjusted value is issued at the output channel.</p>
<p>Automatic operation</p> 	<p>The channel operates as a "normal" analog output channel and can be controlled by PLC program.</p>

Potentiometer

For each channel there is a potentiometer on the front side. Here you can preset an analog value from min. up to max. of the nominal range.

If the potentiometer is turned in the clockwise direction beyond the *max.* position, then the overdrive region is reached. Hardware conditionally an exact marking of the ranges is not possible. As soon as you turn the switch into position "H" (manual operation), the value adjusted by the potentiometer is issued at the according output channel.

Depending on the module there are the following ranges:



Order no.	Nominal range (min. ... max.)	max. overdrive region
VIPA 332-5HD50	4...20mA	ca. 24mA
VIPA 332-5HD60	0...10V	ca. 12V

Channel error by switching to manual operation

The switch to *manual operation* is interpreted as a channel error. The appropriate bit for channel errors in byte 7 of the diagnostics record set 1 is set.

An Interrupt_{going} is only possible if all by group diagnostics activated switches are turned to automatic operation.

More can be found in the chapter "Diagnostics" above.



Danger!

With the modules you can cause a jump in the analog value by means of the switch, independently of the CPU operation mode, as long as the module is power supplied. This could lead to material damage or personal injury!

Please regard also that disconnecting res. connecting during operation, the so-called "Hot Swapping", is not possible!

Technische Daten

Order number	332-5HD60
Type	SM 332
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	80 mA
Power loss	3.5 W
Technical data analog outputs	
Number of outputs	4
Cable length, shielded	-
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	130 mA
Voltage output short-circuit protection	✓
Voltage outputs	✓
Min. load resistance (voltage range)	1 kΩ
Max. capacitive load (current range)	1 μF
Output voltage ranges	0 V ... +10 V
Operational limit of voltage ranges	+/-0.4%
Basic error limit voltage ranges	+/-0.2%
Current outputs	-
Max. in load resistance (current range)	-
Max. inductive load (current range)	-
Output current ranges	-
Operational limit of current ranges	-
Basic error limit current ranges	-
Settling time for ohmic load	1.5 ms
Settling time for capacitive load	1.5 ms
Settling time for inductive load	-
Resolution in bit	12
Conversion time	0.5 ms all channels
Substitute value can be applied	yes
Output data size	8 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	-
Process alarm	no
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	green LED
Group error display	none
Channel error display	none
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-
Max. potential difference between inputs (U _{cm})	-
Max. potential difference between Mana and Mintern (U _{iso})	DC 75 V/ AC 60 V
Max. potential difference between inputs and Mana (U _{cm})	-
Max. potential difference between inputs and Mintern (U _{iso})	-
Max. potential difference between Mintern and outputs	-

Order number	332-5HD60
Insulation tested with	DC 500 V
Datasizes	
Input bytes	0
Output bytes	8
Parameter bytes	21
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	250 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	-

The error limits were determined with a load R=10Ω.

Additional Technical Data

Order number	VIPA 332-5HD60
Suppression of interference, Limits of error	
Crosstalk between the outputs	> 40dB
Temperature error (with reference to the output range)	±0.01%/K
Linearity error (with reference to the input range)	±0.15%
Repeatability (in steady state at 25°C, referred to output range)	±0.05%
Output ripple; range 0 to 50kHz (referred to output range)	±0.05%
Data for selecting an actuator	
Voltage outputs - Short-circuit protection - Short-circuit current	yes 25mA
Destruction limit against voltage/currents applied from outside - Voltage at outputs to M _{ANA} - Current	max. 15V max. 30mA
Connecting actuators -conductor connection	possible

Chapter 4 Analog In/Output Modules

Overview This chapter contains a description of the structure and the operation of the VIPA analog in/output modules.

Content	Topic	Page
	Chapter 4 Analog In/Output Modules.....	4-1
	General	4-2
	Analog value representation	4-3
	Parameterization	4-5
	334-0KE00 - AI 4/AO 2x12Bit.....	4-7

General

Cables for analog signals

For analog signals you should use isolated cables to reduce interference. The cable screening should be grounded at both ends. If there are differences in the potential between the cable ends, there may occur a potential compensating current that could disturb the analog signals. In this case you should ground the cable screening only at one end.



Note!

Please take always care of the correct polarity when connecting!

Please install short circuits at non-used inputs by connecting the positive contact with the channel ground.

Please leave the output pins of not used channels disconnected and configure the *output type* of the channel to "deactivated".

In this way the cycle time of the module gets shorter.

Parameterization

The module may be configured by means of a hardware configuration or rather during run time by SFCs.

After PowerON, the module has the following default settings:

- Input range: Pt100 Climate (RTD-4L)
- Output range: voltage 0 ... 10V

Analog value representation

General As soon as a measuring value exceeds the overdrive res. underdrive range, the following value is returned:

Measuring value > Overdrive range: 32767 (7FFFh)

Measuring value < Underdrive range: -32768 (8000h)

At parameterization error or de-activated analog part the measuring value 32767 (7FFFh) is returned. When leaving the defined range during analog output 0V is issued.

In the following all measuring ranges are specified, which are supported by the analog part. With the formulas it may be converted between measuring and analog value.

Numeric notation in Siemens S7 format The analog values are represented in two's complement format.

		Analog value															
		High byte							Low byte								
Bit number		15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Resolution	SG	Analog value (word)															
12bit + sign	SG	Relevant output value												X	X	X	

* The least significant irrelevant bits of the output value are marked by "X".

Sign bit (SG) The algebraic sign bit is represented by Bit 15. Here it is essential:

Bit 15 = "0" → positive value

Bit 15 = "1" → negative value

Voltage measuring range 0 ... 10V Formulas for the conversion:

$$Value = 27648 \cdot \frac{U}{10}, U = Value \cdot \frac{10}{27648}$$

U: voltage, Value: decimal value

0...10V	dez.	hex.	Range
> 11.759	32767	7FFFh	Overflow
11.759V	32511	7EFFh	Overdrive range
⋮	⋮	⋮	
⋮	⋮	⋮	
10V	27648	6C00h	Nominal range
⋮	⋮	⋮	
⋮	⋮	⋮	
0V	0	0	
Negative values not possible			Underdrive range

Resistance measurement R-4L (0 ... 10kΩ)

Formulas for the conversion:

$$Value = 27648 \cdot \frac{R}{10000}, \quad R = Value \cdot \frac{10000}{27648}$$

R: resistance value, Value: decimal value

10kΩ	dez.	hex.	Range
11.852kΩ	32767 32512	7FFFh 7F00h	Overflow
11.759kΩ . .	32511 27649 . .	7EFFh 6C01h . .	Overdrive range
10kΩ 7.5kΩ 361.7mΩ 0Ω	27648 20736 1 0	6C00h 5100h 0001h 0000h	Nominal range
Negative values physically not possible			Underdrive range

Resistance thermometer (Pt100 Climate)

With Pt 100 the temperature is directly shown with the adjusted unit. Here applies: 1 Digit = 0.01 temperature unit.

Pt100	dec.	hex.	Pt100	dec.	hex.	Range
in °C (1digit=0.01°C)			in °F (1digit=0.01°F)			
>155.0	32767	7FFFh	>311.0	32767	7FFFh	Overflow
155.0 . .	15500 . .	3C8Ch . .	311.0 . .	31100 . .	797Ch . .	Overdrive range
130.0 . .	13000 . .	32C8h . .	266.0 . .	26600 . .	67E8h . .	Nominal range
-120.0 . .	-12000 . .	D120h . .	-184.0 . .	-18400 . .	B820h . .	Underdrive range
-145.0	-14500	C75Ch	-229.0	-22900	A68Ch	Underflow
< -145.0	-32768	8000h	<-229.0	-32768	8000h	Underflow

Voltage output range 0 ... 10V

Formulas for the conversion:

$$Value = 27648 \cdot \frac{U}{10}, \quad U = Value \cdot \frac{10}{27648}$$

U: voltage, Value: decimal value

0...10V	dez.	hex.	Range
0V . .	32767 . .	7FFFh . .	Overflow
11.76V . .	32511 . .	7EFFh . .	Overdrive range
10V . . 0V	27648 . . 0	6C00h . . 0	Nominal range
. . 0V	. . -6912	. . E500h	Underdrive range
. 0V	. -32768	. 8000h	Underflow

Parameterization

Overview

There are the following possibilities for parameterization:

- Parameterization by hardware configuration of Siemens SIMATIC manager or with WinPLC7 from VIPA.
- Parameterization during run time by means of SFCs.

Parameterization by hardware configuration

To be compatible to the Siemens SIMATIC manager the following steps are to be accomplished:

- Start the hardware configurator from Siemens
- Create a new project
- Configure your CPU.
- Link-up your System 300V modules in the plugged-in sequence starting with slot 4.
- Configure the analog in/output module as module from Siemens with the order number 6ES7 334-0KE00-0AB0.

The analog modules may be found at the hardware catalog at *Simatic 300 > SM-300*.

- If needed parameterize the CPU respectively the modules. The parameter window appears as soon as you double click on the according module. At this window the according parameter can be changed.
- Save your project, switch the CPU to STOP and transfer your project to the CPU. As soon as the CPU is switched to RUN the parameters are transferred to the connected modules.

Parameters

The following parameters may be adjusted at the analog in/output module:

- Starting address of the data
- Input area (de-activated, integration time, measuring type/range)
- Output area (de-activated, voltage output)

A closer description of the parameters may be found below.

Parameterization during run time by means of SFCs

If the module gets parameters, which are not supported by the module, these parameters are interpreted as wrong parameters and an error is initialized via the measuring value 32767 (7FFFh).

At the parameterization, a 14byte long parameter area is set in the record set 1. Deploying the SFCs 55, 56 and 57, you may alter parameters during run time and transfer them to the module.

Parameter record set 1

Byte	Bit 7 ... Bit 0				
0	Bit 7 ... 0: not relevant				
1	Integration time Bit 1, 0: Channel 0 01: 16.6ms Bit 3, 2: Channel 1 10: 20ms Bit 5, 4: Channel 2 Bit 7, 6: Channel 3				
2	Measuring channel 0 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	<i>Measuring type</i>	<i>Bit 7...4</i>	<i>Measuring range</i>	<i>Bit 3...0</i>
3	Measuring channel 1 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	de-activated	0000	de-activated	0000
4	Measuring channel 2 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	Voltage	0001	0 ... 10V	1000
5	Measuring channel 3 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	Resistance R-4L	0100	10kΩ	1001
5	Measuring channel 3 Bit 3 ... 0: Measuring range Bit 7 ... 4: Measuring type	Thermo- meter RTD-4L	1000	Pt100 Climate	0000
6	Output channel 0 Bit 3 ... 0: Output range Bit 7 ... 4: Output type	<i>Output type</i>	<i>Bit 7...4</i>	<i>Output range</i>	<i>Bit 3...0</i>
7	Output channel 1 Bit 3 ... 0: Output range Bit 7 ... 4: Output type	de-activated	0000	de-activated	0000
7	Output channel 1 Bit 3 ... 0: Output range Bit 7 ... 4: Output type	Voltage	0001	0 ... 10V	1000
8 ... 13	not relevant				

Voltage measuring via channel 2 and 3

Please regard voltage measurement is only possible by channel 2 and 3.

334-0KE00 - AI 4/AO 2x12Bit

Order data AI 4/AO 2x12Bit VIPA 334-0KE00

Description There are up to 4 analog inputs and 2 analog outputs, which functions may be parameterized by groups.
The module has to be provided with external DC 24V.

- Properties**
- 4 inputs in 2 groups (1. group only Pt100)
 - 2 outputs in one group
 - Measuring type parameterizable per channel
 - voltage
 - resistor
 - temperature
 - Type of output parameterizable per channel group
 - voltage
 - isolated between backplane bus and load voltage

- Parameterization** After PowerON, the module has the following default settings:
- Input range: Pt100 Climate (RTD-4L)
 - Output range: voltage 0 ... 10V


The module is to be configured as module from Siemens with order number 6ES7 334-0KE00-0AB0.



Note!

The deployment of the module at the active backplane bus is not possible!


Structure



Pin assignment

Circuit diagram

334-0KE00



Attention!

Please regard that the module VIPA 334-0KE00 does not have hardware precautions against wrong parameterization. The setting of the according measuring range is exclusively at the project engineering. At the project engineering you should be very careful.

Please regard also that disconnecting/res. connecting during operation, the so-called "Hot Swapping", is not possible!

Technical data

Order number	334-0KE00
Type	SM 334
SPEED-Bus	-
Current consumption/power loss	
Current consumption from backplane bus	95 mA
Power loss	2 W
Technical data analog inputs	
Number of inputs	4
Cable length, shielded	100 m
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	40 mA
Voltage inputs	✓
Min. input resistance (voltage range)	100 kΩ
Input voltage ranges	0 V ... +10 V
Operational limit of voltage ranges	+/-0.7%
Basic error limit voltage ranges with SFU	+/-0.5%
Current inputs	-
Min. input resistance (current range)	-
Input current ranges	-
Operational limit of current ranges	-
Basic error limit current ranges with SFU	-
Resistance inputs	✓
Resistance ranges	10000 Ohm
Operational limit of resistor ranges	+/-3.5%
Basic error limit	+/-2.8%
Resistance thermometer inputs	✓
Resistance thermometer ranges	Pt100
Operational limit of resistance thermometer ranges	+/-0.1%
Basic error limit thermoresistor ranges	+/-0.8%
Thermocouple inputs	-
Thermocouple ranges	-
Operational limit of thermocouple ranges	-
Basic error limit thermoelement ranges	-
Programmable temperature compensation	-
External temperature compensation	-
Internal temperature compensation	-
Resolution in bit	12
Measurement principle	Sigma-Delta
Basic conversion time	350 ms
Noise suppression for frequency	50 Hz/60 Hz
Initial data size	8 Byte
Technical data analog outputs	
Number of outputs	2
Cable length, shielded	100 m
Rated load voltage	DC 24 V
Reverse polarity protection of rated load voltage	✓
Current consumption from load voltage L+ (without load)	40 mA
Voltage output short-circuit protection	✓
Voltage outputs	✓
Min. load resistance (voltage range)	1 kΩ
Max. capacitive load (current range)	1 μF
Output voltage ranges	0 V ... +10 V
Operational limit of voltage ranges	+/-1%
Basic error limit voltage ranges with SFU	+/-0.8%
Current outputs	-
Max. in load resistance (current range)	-

Order number	334-0KE00
Max. inductive load (current range)	-
Output current ranges	-
Operational limit of current ranges	-
Basic error limit current ranges with SFU	-
Settling time for ohmic load	0.8 ms
Settling time for capacitive load	0.8 ms
Settling time for inductive load	0.3 ms
Resolution in bit	12
Conversion time	0.5 ms per channel
Substitute value can be applied	-
Output data size	4 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	no
Process alarm	no
Diagnostic interrupt	no
Diagnostic functions	no
Diagnostics information read-out	none
Supply voltage display	none
Group error display	none
Channel error display	none
Isolation	
Between channels	-
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-
Max. potential difference between inputs (Ucm)	DC 1 V
Max. potential difference between Mana and Mintern (Uiso)	DC 75 V/ AC 60 V
Max. potential difference between inputs and Mana (Ucm)	DC 1 V
Max. potential difference between inputs and Mintern (Uiso)	-
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	8
Output bytes	4
Parameter bytes	21
Diagnostic bytes	0
Housing	
Material	PPE
Mounting	Rail System 300
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	210 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

Additional Technical Data

Order number	VIPA 334-0KE00
Analog value generation of the inputs	
Basic conversion time	nx72ms
Smoothing of the measured values	none
Suppression of interference, Limits of error of the inputs	
Noise suppression for $f=n \times (f1 \pm 1\%)$ ($f1=$ interference frequency, $n=1,2,\dots$)	
- Common mode interference ($U_{CM} < 13V$)	> 80dB
- Series mode noise (peak value of noise < Nominal value of input range)	> 80dB
Crosstalk between the inputs	> 50dB
Temperature error (with reference to the input range)	$\pm 0.01\%/K$
Linearity error (with reference to the input range)	$\pm 0.005\%$
Repeatability (in steady state at 25°C, referred to input range)	$\pm 0.05\%$
Suppression of interference, Limits of error of the outputs	
Crosstalk between outputs	> 40dB
Temperature error (with reference to the output range)	$\pm 0.005\%/K$
Linearity error (with reference to the output range)	$\pm 0.1\%$
Repeatability (in steady state at 25°C, (with reference to the output range)	$\pm 0.05\%$
Output ripple; Range 0 to 50kHz (with reference to the output range)	$\pm 0.05\%$
Data for selecting a sensor	
Maximum input voltage for voltage input (destruction limit)	30V
Connection of the sensor	
- for measuring voltage	possible
- for measuring resistance	
as 2-conductor connection	possible
as 3-conductor connection	possible
as 4-conductor connection	possible
Characteristic linearization	
- for resistance thermometer	Pt100 Climate
Temperature compensation	no
Technical unit for temperature measurement	°C
Data for selecting an actuator	
Load resistance (in the nominal range of the outputs)	
- for voltage outputs	min. 1kΩ
capacitive load	max. 1μF
Destruction limit against voltages/currents	
- Voltages at outputs to M_{ANA}	max. 16V (30V for 10s)
- Current	not possible
Connection of actuators	
- for voltage output	
2-conductor connection	possible
4-conductor connection	not possible

Chapter 5 Analog I/O modules FAST - SPEED-Bus

Overview

Contents of this chapter are the structure and the functionality of the fast analog modules for VIPA SPEED-Bus.

The modules may only be used at SPEED-Bus slots at the left side of the CPU.

Content

Topic	Page
Chapter 5 Analog I/O modules FAST - SPEED-Bus	5-1
General	5-2
Analog value representation	5-3
Operating modes.....	5-4
Addressing at SPEED-Bus	5-5
Project engineering	5-6
Parameterization	5-10
SFC 193 - Oscilloscope-/FIFO function	5-15
Example for the oscilloscope function.....	5-18
Example for the FIFO function.....	5-21
Diagnostics.....	5-25
331-7AF70 - AI 8x16Bit I	5-28
331-7BF70 - AI 8x16Bit U.....	5-32

General

Cables for analog signals

For analog signals you should use isolated cables to reduce interference. The cable screening should be grounded at both ends. If there are differences in the potential between the cable ends, there may occur a potential compensating current that could disturb the analog signals. In this case you should ground the cable screening only at one end.

Connecting sensors

Depending on the module the following sensors may be connected to the analog input modules:

- Current sensor $\pm 20\text{mA}$
- Voltage sensor $\pm 10\text{V}$



Note!

Please take care of the correct polarity when installing the sensors! Please install short circuits at non-used inputs by connecting the positive contact with the channel ground of the according channel.

Parameterization

The modules may be parameterized by hardware configuration respectively at run time by means of SFCs.

Diagnostic functions

The modules have diagnostics capability. The following errors can release a diagnostic:

- Error in parameterization
- Process interrupt lost
- Measuring range over-/underflow
- External power supply is missing

Process interrupts

The following events can be defined by parameterization to release a process interrupt:

- Limit overflow
- Limit underflow
- End of cycle as soon as measuring value conversion of every channel has finished.

At a process interrupt 4bytes of process interrupt data are transferred.

The process interrupts are deactivated when using oscilloscope- or FIFO functions.

Analog value representation

Numeric representation in Siemens S7 format

The analog values are only processed by the CPU in binary representation. Hereby the process signals are transformed into digital format in the analog module and passed on to the CPU as word variable.

The digitized analog value is the same for input and output values at the same nominal range.

The analog value is represented as two's-complement

		Analog value															
		High byte							Low byte								
Bit number		15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
15bit + SG	SG	Measuring value															

Sign bit (SG) The algebraic sign bit is represented by Bit 15. Here it is essential:
 Bit 15 = "0" → positive value
 Bit 15 = "1" → negative value

Behavior at error As soon as a measured value exceeds the overdrive region respectively falls below the underdrive region, the following value is issued:
 Measuring value > end of overdrive region: 32767 (7FFFh)
 Measuring value < end of underdrive region: -32768 (8000h)

At a parameterization error the value 32767 (7FFFh) is issued.

Digital/analog conversion

In the following there are the measuring ranges listed. The support depends on the analog module.

The here listed formulas allow you to transform an evaluated measuring value (digital value) to a value assigned to the measuring range and vice versa.

+/- 10V

Voltage	Decimal	Hex
-10V	-27648	9400
-5V	-13824	CA00
0V	0	0
+5V	+13824	3600
+10V	+27648	6C00

Formulas for calculation:

$$Value = 27648 \cdot \frac{U}{10}, \quad U = Value \cdot \frac{10}{27648}$$

U: voltage, Value: Decimal value

+/- 20mA

Current	Decimal	Hex
-20mA	-27648	9400
-10mA	-13824	CA00
0mA	0	0
+10mA	+13824	3600
+20mA	+27648	6C00

Formulas for calculation:

$$Value = 27648 \cdot \frac{I}{20}, \quad I = Value \cdot \frac{20}{27648}$$

I: current, Value: Decimal value

Operating modes

Mode	There are the following modes at the analog input modules to be set by means of a hardware configuration at the Siemens SIMATIC Manager.
Standard mode	<p>At the standard mode the analog values of the 8 input channels were cyclically read up to 25μs, converted to 16bit digital values and transferred to the CPU via SPEED-Bus.</p> <p>Only for cycle times \geq 200μs an end of cycle interrupt may be activated. This is generated as soon as there are new measuring values available.</p>
Oscilloscope mode	<p>With the oscilloscope mode the digitized input values were buffered in the memory of the module. There is space for a total of 65536 measuring values.</p> <p>At this mode hardware interrupts are not supported.</p> <p>Recording may be started manually or automatically, whereas there is reacted at a rising respectively falling edge of the measuring signal. As soon as the memory of the module is full the recording ends automatically.</p>
FIFO mode	<p>If FIFO mode is activated the input values of channel CH0 to CH7 are stored at a buffer. There is space for 8190 values each channel. These may cyclically be read in packets.</p> <p>At overflow the memory contents is overwritten from the beginning and an error is reported.</p>
SFC 193	The activation of the oscilloscope-/FIFO function as well as the readout of the stored data happens by means of the VIPA specific SFC 193.
Parameter	There are a lot of parameters to adapt these functions to your requirements. The parameters may be set by GSD file respectively at run time by SFC 58.

Addressing at SPEED-Bus

Overview

To provide specific addressing of the installed peripheral modules, certain addresses must be allocated in the CPU.

With no hardware configuration present, the CPU assigns automatically peripheral I/O addresses during boot procedure depending on the plug-in location amongst others also for plugged modules at the SPEED-Bus.

Maximal pluggable modules

In the hardware configurator from Siemens up to 8 modules per row may be parameterized. At deployment of SPEED7 CPUs up to 32 modules at the standard bus and 10 further modules at the SPEED-Bus may be controlled. CPs and DP masters that are additionally virtual configured at the standard bus are taken into the sum of 32 modules at the standard bus.

For the project engineering of more than 8 modules you may use virtual line interface connections. For this you set in the hardware configurator the module IM 360 from the hardware catalog to slot 3 of your 1. profile rail. Now you may extend your system with up to 3 profile rails by starting each with an IM 361 from Siemens at slot 3.

Define addresses by hardware configuration

You may access the modules with read res. write accesses to the peripheral bytes or the process image.

To define addresses, a hardware configuration via a virtual Profibus system by including the SPEEDBUS.GSD may be used. For this, click on the properties of the according module and set the wanted address.

Automatic addressing


If you do not like to use a hardware configuration, an automatic addressing comes into force.

At the automatic address allocation DIOs are mapped depending on the slot location with a distance of 4byte and AIOs, FMs, CPs with a distance of 256byte.

Depending on the slot location the start address from where on the according module is stored in the address range is calculated with the following formulas:

DIOs: $Start\ address = 4 \cdot (slot - 101) + 128$

AIOs, FMs, CPs: $Start\ address = 256 \cdot (slot - 101) + 2048$



Project engineering

Overview

Every module at the SPEED-Bus including the CPU has to be configured as single "VIPA_SPEEDbus" DP slave at a virtual DP master (342-5DA02 V5.0 from Siemens). For this you have to include the GSD speedbus.gse. Every "VIPA_SPEEDbus" DP slave has exactly one slot for the project engineering where you must place the according SPEED-Bus module. The assignment of a SPEED-Bus slave to a SPEED-Bus slot number takes place via the Profibus address starting with 100.


Fast introduction

For the employment of the I/O modules at the SPEED-Bus the inclusion via the GSD-file from VIPA in the hardware catalog is required.

Standard bus

Slot	Module
1	
2	CPU 318-2
X2	DP
X1	MPI/DP
3	
real modules at standard bus	
CPs res. DP master at SPEED-Bus	
	342-5DA02 V5.0

virtual DP master for CPU and all SPEED-Bus modules



- To be compatible with the Siemens SIMATIC manager, you have to execute the following steps:
- Start the hardware configurator from Siemens and include the speedbus.gse for SPEED7 from VIPA.
 - Configure CPU 318-2DP (6ES7 318-2AJ00-0AB0/V3.0) from Siemens.
 - Starting with slot 4, place the System 300 modules in the plugged sequence.
 - Project engineering and connection of the SPEED-Bus-CPs res. DP master at the standard bus as virtual CP 343-1 (343-1EX11) res. CP 342-5 (342-5DA02 V5.0)
 - For the SPEED-Bus you always include, connect and parameterize to the *operating mode* DP master the DP master CP 342-5 (342-5DA02 V5.0) as last module. To this master system you assign every SPEED-Bus module as VIPA_SPEEDbus slave. Here the Profibus address corresponds to the slot number beginning with 100 for the CPU. Place at slot 0 of every slave the assigned module and alter the parameters if needed.
 - Modul platzieren und ggf. Parameter ändern.

Preconditions

The hardware configurator is part of the Siemens SIMATIC manager. It serves for project engineering. The modules that may be configured here are listed in the hardware catalog.

For the employment of the System 300S modules at the SPEED-Bus you have to include the System 300S modules into the hardware catalog via the GSD-file speedbus.gse from VIPA.



Note!

For the project engineering, a thorough knowledge of the Siemens SIMATIC manager and the hardware configurator from Siemens is required!

Include the SPEED7-GSD-file


- Browse to www.vipa.de > Service > Download > GSD- and EDS-Files > Profibus and select the file *Cx000023_Vxxx*.
- Extract the file to your work directory. The speedbus.gse is stored in the directory System_300S.
- Start the hardware configurator from Siemens.
- Close all projects.
- Select **Options** > *Install new GSD-file*.
- Change to the directory System_300S and select the **SPEEDBUS.GSE**. The modules of the System 300S from VIPA are now included in the hardware catalog at: *Profibus-DP / Additional field devices / I/O / VIPA_SPEEDbus*.

Steps of project engineering

The following text describes the approach of the project engineering in the hardware configurator from Siemens at an abstract sample.

The project engineering is separated into following parts:

- Project engineering of the modules at the standard bus
- Project engineering of the SPEED-Bus modules in a virtual master system (speedbus.gse required)




Preconditions

For the employment of the System 300S modules at the SPEED-Bus you have to include the System 300S modules into the hardware catalog via the GSD-file speedbus.gse from VIPA.

Project engineering of the modules at the standard bus

The modules at the right side of the CPU at the standard bus are configured with the following approach:

- Start the hardware configurator from Siemens with a new project and insert a profile rail from the hardware catalog.
- Place the following Siemens CPU at slot 2:
CPU 318-2DP (6ES7 318-2AJ00-0AB0/V3.0)
- Include your System 300V modules at the standard bus in the plugged sequence starting with slot 4.
- Parameterize the CPU res. the modules where appropriate. The parameter window opens by a double click on the according module.
- To extend the bus you may use the IM 360 from Siemens where you can connect up to 3 further extension racks via the IM 361. Bus extensions are always placed at slot 3.
- Save your project.



Note!

To extend the bus you may use the IM 360 from Siemens where you can connect up to 3 further extension racks via the IM 361. Bus extensions are always placed at slot 3.

Project engineering of all SPEED-Bus modules in a virtual master system


The slot assignment of the SPEED-Bus modules and the parameterization of the in-/output periphery happens via a virtual Profibus DP master system. For this, place as last module a DP master (342-5DA02 V5.0) with master system.

For the employment of the System 300S modules at the SPEED-Bus the inclusion of the System 300S modules into the hardware catalog via the GSD-file speedbus.gse from VIPA is required.

After the installation of the speedbus.gse you may locate under *Profibus DP / Additional field devices / I/O / VIPA_SPEEDbus* the DP slave system vipa_speedbus.

Now include for the CPU and every module at the SPEED-Bus a slave system "vipa_speedbus".

Set as Profibus address the slot no. (100...110) of the module and place the according module from the hardware catalog of VIPA_speedbus to slot 0 of the slave system.



The according module is to be taken over from the HW Catalog of vipa_speedbus to slot 0.

Parameterization

Overview

After Power ON the diagnostics function of every channel is deactivated. For parameterization the parameter data of the module are transferred by the Siemens SIMATIC manager to the CPU.

There is also the possibility to change parameters during run time by means of SFCs.

Place module

- Start the hardware configurator and install speedbus.gse for SPEED7 from VIPA.
- Configure CPU 318-2DP (6ES7 318-2AJ00-0AB0/V3.0) from Siemens.
- Include your System 300V modules at the standard bus in the plugged sequence starting with slot 4.
- For the SPEED-Bus you always include, connect and parameterize to the *operating mode* DP master the DP master CP 342-5 (342-5DA02 V5.0) as last module.
- To this master system you assign every SPEED-Bus module as VIPA_SPEEDbus slave. Here the Profibus address corresponds to the slot number beginning with 100 for the CPU.
- Place at slot 0 of every slave the assigned module and alter the parameters if needed. In this way also the project engineering of the analog modules takes place.

Parameterize the module

Via double click on the wanted module in the hardware configurator the corresponding parameter dialog is opened.

You may alter the following parameters there:

- Start address of the data of the module stored in the CPU
- Enable interrupt / Mode
(end of cycle, oscilloscope-/FIFO mode, diagnostics, limit)
- Limit (upper/lower)
- Oscilloscope parameter (channel, pre-trigger, level, condition)
- Cycle time (scan time at oscilloscope-/FIFO mode)

Save and transfer project

- Save and compile your project.
- Set your CPU to STOP.
- Transfer your project into the CPU.

As soon as you switch the CPU into RUN, the parameters are transmitted to the analog input module.

More detailed information about the parameters may be found at the following pages.

Structure of the parameter bytes

The parameterization happens during hardware configuration. Here the following parameter data are transferred:

Length in Byte	Record set	Description
4	A0h	Limit upper/lower channel 0
4	A1h	Limit upper/lower channel 1
...
4	A7h	Limit upper/lower channel 7
2	A8h	Cycle time / (sampling time at oscilloscope-/FIFO mode)
2	7Fh	Interrupt enable / Operating mode
5	BEh	Oscilloscope (Parameter for oscilloscope mode)

Using the SFCs 55, 56, 57 and 58 every parameter of the module may be transferred to the module during run time.

Here the favored parameters are transferred as record set by the user program by means of SFCs.

By this parameters may be transferred, which are not supported by the Siemens SIMATIC manager.

Record set A0...A7h
Limit upper/lower

Upper and lower limits may be set for the corresponding channel by record set A0h...A7h. As soon as your measured value leaves the work area defined by the limit values, a limit value interrupt is released, if activated.

The record set has the following structure:

Word		Default	
		Byte 0	Byte 1
0	Limit upper	7FFFh	
2	Limit lower	8000h	

Record set A8h
Cycle time / Sampling time

With this record set a factor may be set, which sets the cycle time multiplied by 100µs, this is independent of the number of activated channels. The cycle time of 25µs is set by 0.

During hardware configuration the cycle time may be directly chosen.

Is oscilloscope respectively FIFO mode activated this time represents the sampling time the read values are stored.

Range of values: 0 ... 600

The record set has the following structure:

Word		Default	
		Byte 0	Byte 1
0	Cycle time / sampling time	0001h	

As soon as this record set is transferred during recording at oscilloscope or FIFO operation the recording is stopped.

Record set 7Fh
Interrupt enable /
Operating mode

Here the interrupt behavior and the operating mode of the module may be adjusted. Is the diagnostic interrupt deactivated during run-time and a diagnostic interrupt is just pending, there may no diagnostic_{going} be generated to reset the SF-LED. Please do not execute a diagnostic interrupt deactivation during run time!

As soon as this record set is transferred during recording at oscilloscope or FIFO operation the recording is stopped.

The record set has the following structure:

Byte	Bit 7 ... Bit 0	Default
0	Interrupt enable / Operating mode Bit 0: reserved Bit 5 ... 1: Operating mode 0 0000: without end of cycle interrupt 0 0010: with end of cycle interrupt 0 0100: Oscilloscope: Channel 0 0 1000: Oscilloscope: Channels 0 ... 1 0 1100: Oscilloscope: Channels 0 ... 3 1 0000: Oscilloscope: Channels 0 ... 7 0 0001: FIFO mode Bit 6: Diagnostic interrupt enable Bit 7: reserved	00h
1	Limit interrupt enable Bit 0: Channel 0 ... Bit 7: Channel 7	00h

with/without end of
cycle interrupt

Setting *with* or *without end of cycle interrupt* the module may be used in standard operating mode. Here the 8 channels are read synchronously and allocated as 16bit value.

Setting *with end of cycle interrupt* an end of cycle interrupt is generated as soon as new measuring values are available. Please note that end of cycle monitoring is only available starting from a module cycle time of 200µs.

Oscilloscope
operating mode

In the oscilloscope mode the fragmentation of the memory is configured by number of channels to be recorded. The memory has a total space for 65536 measuring values. For memory fragmentation see the following table:

Byte 0, Bit 5 ... 1	Operating mode	Channel	Number of words	Values each channel
0 0100	Oscilloscope: Channel 0	CH0	1 x 64 k	65.536
0 1000	Oscilloscope: Ch. 0 ... 1	CH0, CH1	2 x 32 k	32.768
0 1100	Oscilloscope: Ch. 0 ... 3	CH0 ... CH3	4 x 16 k	16.384
1 0000	Oscilloscope: Ch. 0 ... 7	CH0 ... CH7	8 x 8 k	8.192

FIFO operating
mode

During FIFO operation all of the 8 channels are recorded and stored at a buffer. These values may be read as packets by means of the user program. At overflow the memory contents is overwritten from the beginning and an error is reported by *RETVAl*.

The buffer offers place for 8190 values per channel.

Diagnostic interrupt enable

With activated diagnostic interrupt, in the case of an error and after error correction a diagnostic interrupt is released to the CPU.
 With a diagnostic interrupt the CPU interrupts its user program and jumps to OB 82. There detailed diagnostic information can be requested by means of the SFC 51 respectively SFC 59. The diagnostics data are consistent during OB 82 operation.

Limit interrupt enable

A work area may be defined by the parameters *limit upper/lower*. If your measuring signal leaves this work area and the limit interrupt is enabled, then the module releases a process interrupt of the corresponding channel.
 Here the CPU interrupts its user program and jumps to OB 40. There it may be reacted accordingly to the process interrupt. With leaving the OB 40 the process interrupt is acknowledged at the corresponding module.
 Please note that at oscilloscope-/FIFO operating mode the process interrupts are not supported.

Record set BEh
 Oscilloscope

The parameters of the oscilloscope operation may be set with this record set.
 As soon as this record set is transferred during recording at oscilloscope or FIFO operation the recording is stopped.
 The record set has the following structure:

Byte	Bit 7 ... 0	Default
0	Bit 2 ... 0: Trigger channel 000: CH0 ... 111: CH7 Bit 7 ... 3: reserved	00h
1	Bit 6 ... 0: Pre-trigger (%) 00h: 0% Pre-trigger ... 64h: 100% Pre-trigger Bit 7: reserved	00h
2, 3	Bit 15 ... 0: Trigger level 8100h: -32512 (decimal) ... 0000h: 0 ... 7EFFh: 32511 (decimal)	00h
4	Bit 1 ... 0: Trigger condition 00: rising edge (automatic start) 01: falling edge (automatic start) 10: manual start Bit 7 ... 2: reserved	00h

Trigger channel With this parameter a channel may be defined to be triggered, this means the recording is to be started on its rising or falling edge. At manual operation this setting will be ignored.

Pre-trigger (%) Here a number per cent may be set as pre-trigger. On this way values may also be picked out, which were buffered before the trigger event occurred. At manual operation this setting will be ignored.
 In the following there is a formula to calculate the number n of values in the buffer, which were buffered before the trigger event occurred. This value depends on the parameters pre-trigger and the number of channels to be buffered.

$$n = \frac{8192 \times \text{Pre-trigger}}{100} \times \frac{8}{\text{Number channels}}$$

Integer

Trigger level At this parameter a threshold may be set, which when exceeded/fallen below generates a trigger event. At manual operation this setting will be ignored.

Trigger condition Here the start condition for recording may be set. To start the recording there is basically differentiated between an automatic operation with a triggered edge and a manual operation.

SFC 193 for controlling The oscilloscope/FIFO operation is controlled by means of the SFC 193. This is described at the following pages.

SFC 193 - Oscilloscope-/FIFO function

Description The SFC 193 serves for controlling the oscilloscope-/FIFO function. It allows to start the recording and to read the buffered data. Depending upon the parameterization there are the following possibilities:

Oscilloscope operation

- Depending on the trigger condition at edge evaluation the monitoring of the configured channel may be started respectively at manual operation the recording may be started.
- The recorded measuring values may be accessed by the SFC 193 as soon as the buffer is full.

FIFO operation

- Start the recording
- Read the puffer at any time



Note!

The SFC may only be called from on level of priority e.g. only from OB 1 or OB 35.

The module is to be parameterized before.

For starting and reading in each case the SCF 193 is to be called. The differentiation of both variants takes place in the parameter *MODE*.

Parameter

Parameter	Declaration	Data type	Function depending on MODE
REQ	IN	BOOL	Execute function (start/read)
LADR	IN	WORD	Base address of the module
MODE	IN	WORD	Mode (start/read)
CHANNEL	IN	BYTE	Channel to be read
OFFSET	IN	DWORD	Address offset for reading (not FIFO operation)
RECORD	IN	ANY	Memory for the read data
RETVAL	OUT	WORD	Return value (0=OK)
BUSY	OUT	BOOL	Function is busy
TIMESTAMP	OUT	DWORD	Time stamp (only at edge evaluation)
LEN	INOUT	DWORD	Number of values to be handled per channel

REQ Depending on the set MODE when the bit is set the recording respectively the reading may be started.

Depending on the trigger condition at edge evaluation the monitoring of the configured channel may be started respectively at manual operation the recording may be started.

The data are read from the module, if "read" is set at *MODE*.

LADR Logical basic address of the module

MODE	<p>The SFC 193 may be called with 3 different modes. The corresponding mode may be set by the parameter <i>MODE</i>. The configured mode is executed by setting <i>REQ</i>.</p> <p>The following values are supported:</p> <p>01h: Starts recording respectively edge monitoring depending upon the parameterization.</p> <p>00h: Read data within several cycles until <i>BUSY</i> = 0.</p> <p>80h: Read data with one access.</p>
CHANNEL	<p>Here the channel is specified to be read. With each call one channel may be read. This parameter is irrelevant at start calls with <i>MODE</i> = 01h.</p>
OFFSET	<p>Offset specifies an address offset for the reading process. By this you get access to sub-ranges of the recorded data. The value for the maximum offset depends on the number of values, which were recorded per channel. <i>OFFSET</i> is not supported in FIFO operation. It will be ignored.</p>
RECORD	<p>Here an area for the read values to be stored at may be defined.</p> <p>In FIFO operation every value of the selected channel may be read, which were stored up to the time of start reading. Please regard that the buffer has a sufficient size for the data to be buffered, otherwise an error is reported.</p>
BUSY	<p><i>BUSY</i> = 1 indicates that the function just processed. <i>BUSY</i> = 0 indicates that the function is finished.</p>
TIMESTAMP	<p>There is an internal clock with a resolution of 1μs running in every SPEED-Bus module. The returned value corresponds to the time at the SPEED-Bus module, on which the trigger event occurred.</p> <p><i>TIMESTAMP</i> is only available at the edge triggered oscilloscope operation. It is valid as long as the job is running (<i>RETVAL</i> = 7xxxh) and bit 4 of byte 0 is set respectively the job has been finished without an error (<i>RETVAL</i> = 0000h).</p>
LEN	<p>The length parameter realized as IN/OUT is variably interpreted depending on the selected mode at the function call.</p> <p>Mode: start (MODE: = 01h)</p> <p>At <i>MODE</i> = 01h this parameter may only be used at the manual oscilloscope start. Here the requested number of values per channel to be buffered may be assigned. In this mode there is no value reported by <i>LEN</i>.</p> <p>Mode: read (MODE: = 00h or 80h)</p> <p>At <i>MODE</i> = 00h respectively 80h the number of values to be read may be set. This parameter is ignored in FIFO operation. The number of the read values is returned by <i>LEN</i>.</p>

RETVAL (Return value) In addition to the module specific error codes listed here, there general SFC error information may be returned as well. More may be found at the operation list.

RETVAL	Description depending on the BUSY-Bit	BUSY
Byte		
0	Bit 1, 0:	
	00: Call with REQ: = 0 (idle, waiting for REQ = 1)	0
	01: First call with REQ: = 1	1
	10: Subsequent call with REQ: = 1	1
	11: Oscilloscope is just recording	1
	Bit 2: REQ: = 1, but recording was not yet started. (MODE: = 00h or MODE: = 80h)	0
	Bit 3: reserved	-
	Bit 4: Trigger event occurred and recording is just running.	1
	Bit 5: Waiting for trigger event	1
	Bit 7...6: reserved	-
1	Bit 0: reserved	-
	Bit 1: The number of recorded values exceeds the target area defined by RECORD (in words)	0
	Bit 2: The number of the recorded values exceeds the area defined by LEN and OFFSET.	0
	Bit 3: Buffer overflow in FIFO operation.	0
	Bit 7...4:	
	0000: Job finished without an error	0
	0111: Job still running	1
1000: Job finished with error (see following table)	0	

Job finished without an error

RETVAL	Description depending on the BUSY-Bit	BUSY
0000h	Job was finished without an error.	0

Job finished with error

RETVAL	Description depending on the BUSY-Bit	BUSY
8002h:	Oscilloscope-/FIFO function is not configured.	0
8003h:	An internal error occurred - please contact VIPA.	0
8005h:	The selected channel may not be read - wrong channel number.	0
8007h:	The value at OFFSET exceeds the number of recorded values.	0
8090h:	There is no SPEED-Bus module with this address available.	0
80D2h:	LADR exceeds the peripheral address area.	0

Example for the oscilloscope function

Job definition


At this example 4 channels were recorded with 25µs sampling time whereas channel 2 is monitored. As soon as the decimal value 12000 is exceeded by the input signal, a trigger event is generated. 50% of the buffer should contain the last values before the trigger event occurred (pre-trigger) and 50% the values after the event.

Parameterization

The parameterization happens by a hardware configuration of the Siemens SIMATIC manager. Here the integration of the VIPA GSD file speedbus.gse is necessary. More may be found above at "Project engineering".

Parameterize the following module parameters after configuring the system:

Cycle time:	25µs
Operating mode:	Oscilloscope Channels 0 ... 3 (16384 values per channel)
Oscilloscope trigger channel:	2
Oscilloscope pre-trigger (%):	50
Oscilloscope trigger level:	12000
Oscilloscope trigger condition:	rising edge



User program

The SFC 193 calls for starting the oscilloscope recording and for reading the data are implemented in the OB 1 of the user program.

For the simplified representation and for controlling the parameters are handled in a variable table.

```

CALL SFC 193 // start oscilloscope function (1. SFC call)
REQ :=M99.0 // bit to start recording
LADR :=W#16#64 // basic module address
MODE :=W#16#1 // mode: start
CHANNEL :=B#16#0 // not used
OFFSET :=DW#16#0 // not used
RECORD :=DB10 // not used
RETVAL :=MW1110 // return value
BUSY :=M112.0 // busy bit
TIMESTAMP:=MD100 // not used
LEN :=MD114 // length parameter for recording
// (only at "manual start")
U M 99.0 // request bit set by 1. call?
S M 98.1 // yes: set request bit for 2. call
//
R M 99.0 // Reset request bit for 1. call
//
CALL SFC 193 // read data (2. SFC call)
REQ :=M98.1 // bit for reading the data
LADR :=W#16#64 // basic module address
MODE :=W#16#80 // mode: read (complete, 1 access)
CHANNEL :=MB148 // channel to be read
OFFSET :=MD150 // address offset for reading
RECORD :=DB10 // data block for the read values
RETVAL :=MW110 // return value
BUSY :=M112.0 // busy bit
TIMESTAMP:=MD104 // timestamp at trigger event
LEN :=MD114 // length parameter for reading
U M 98.1 // request bit set and
U M 112.0 // busy bit set?
BEB // yes: reading is not yet finished
// finish block
U M 98.1 // request bit is set and
UN M 112.0 // busy bit is not set?
SPBN end // no: jump to label end

L MW 110 // yes: load return value and
T MW 160 // transfer to flag
end: NOP 0
U M 98.1
R M 98.1 // reset request bit from 2. call

```

Process

The recording at oscilloscope operation is started by setting flag 99.0. From this moment on the configured monitoring of channel 2 on the rising edge and the threshold of 12000 begins. With the configured operation mode *Oscilloscope channels 0...3* these channels are recorded, 16384 values each channel.

Exceeding the configured threshold 12000 a trigger event is released. With the pre-trigger of 50% 8192 values per channel were finally recorded, then the recording is finished and the *BUSY* bit is reset.

Now the data may be read. With the configured pre-trigger of 50% the 8193. value is the value, which released the event.

Further reading accesses with e.g. other address offsets or to read values of the other channels may be executed by setting flag 98.1. The oscilloscope recording may be started again by setting flag 99.0.

Variable table

The output of the values 8189 ... 8208 is generated by the address offset of 8188 and the length of 20.

The event was released by the 8193. value (DB10.DBW 8 = 12004), because it has exceeded the configured threshold of 12000.

	Address	Display format	Status value	Modify value
1	// Start recording if flag is "true"			
2	M 99.0	BOOL	false	
3	// Start reading if flag is "true"			
4	M 98.1	BOOL	false	
5	// Return value (2. SFC call: reading data)			
6	MW 110	HEX	VW#16#7000	
7	// Return value is buffered			
8	MW 160	HEX	VW#16#0400	
9	// Busy bit (1. SFC call: activate oscilloscope)			
10	M 1112.0	BOOL	false	
11	// Busy bit (2. SFC call: read data)			
12	M 112.0	BOOL	false	false
13	// Length to be recorded (only at manual mode)			
14	MD 130	DEC	L#0	
15	// Number of values to be read			
16	MD 114	DEC	L#20	L#20
17	// Address offset for reading			
18	MD 150	DEC	L#8188	L#8188
19	// Channel to be read			
20	MB 148	DEC	2	2
21	// Time stamp of trigger event			
22	MD 104	DEC	L#329222049	
23	// Read data			
24	DB10.DBW 0	DEC	11998	
25	DB10.DBW 2	DEC	11994	
26	DB10.DBW 4	DEC	11999	
27	DB10.DBW 6	DEC	11999	
28	DB10.DBW 8	DEC	12004	
29	DB10.DBW 10	DEC	12004	
30	DB10.DBW 12	DEC	12005	
31	DB10.DBW 14	DEC	12004	
32	DB10.DBW 16	DEC	12001	
33	DB10.DBW 18	DEC	11999	
34	DB10.DBW 20	DEC	12001	
35	DB10.DBW 22	DEC	12004	
36	DB10.DBW 24	DEC	12003	
37	DB10.DBW 26	DEC	12000	
38	DB10.DBW 28	DEC	11998	
39	DB10.DBW 30	DEC	11994	
40	DB10.DBW 32	DEC	11994	
41	DB10.DBW 34	DEC	12003	
42	DB10.DBW 36	DEC	12003	
43	DB10.DBW 38	DEC	12004	
44				
45				
46	// Input data of channel 2			
47	PEW 104	DEC		


Example for the FIFO function

Job definition At this example the recorded values of channel 0 were read and the minimum and maximum input value is evaluated.

Parameterization The parameterization happens by a hardware configuration of the Siemens SIMATIC manager. Here the integration of the VIPA GSD file speedbus.gse is necessary. More may be found above at "Project engineering".
Parameterize the following module parameters after configuring the system:

Cycle time: 100µs
Operating mode: FIFO

The oscilloscope parameters (channel, pre-trigger, level, condition) are not necessary for FIFO operation and were ignored.



User program

The SFC 193 calls for starting the FIFO operation and for reading the data are implemented in the OB 35. The OB 35 is to be parameterized that it is cyclically called for operation every 10ms. For the simplified representation and for controlling the parameters are handled in a variable table.

```

UN    M    20.0    // start bit set?
SPB   go                    // no: do not start FIFO function
L     0                    // yes: initialize limits
                        // and start FIFO function

L     32767
T     MW    46    // initialize minimum value
L     -32768
T     MW    48    // initialize maximum value
CALL  SFC  193    // start FIFO function (1. SFC call)
REQ   :=TRUE        // bit starting the FIFO function
LADR  :=W#16#64    // basic module address
MODE  :=W#16#1    // mode: start
CHANNEL :=B#16#0    // not used
OFFSET :=DW#16#0    // not used
RECORD :=DB1        // not used
RETVAL :=MW22        // return value
BUSY  :=M20.1        // busy bit
TIMESTAMP:=MD24    // not used
LEN   :=MD28        // not used
U     M    20.0    // reset start bit
R     M    20.0
S     M    20.2    // start reading if FIFO active
go:  UN    M    20.2    // bit set for reading?
BEB                    // no: finish block
CALL  SFC  193    // read data (2. SFC call)
REQ   :=TRUE        // bit for reading the data
LADR  :=W#16#64    // basic module address
MODE  :=W#16#80    // mode: read (complete, 1 access)
CHANNEL :=MB21        // channel to be read
OFFSET :=DW#16#0    // not used
RECORD :=DB1        // data block for the read values
RETVAL :=MW32        // return value
BUSY  :=M20.3        // busy bit
TIMESTAMP:=MD34    // not used
LEN   :=MD38        // length parameter for reading

L     MD    38    // load length parameter
L     0
==D                    // check if values were read
BEB                    // no: finish block
                        // every value in the buffer was read
                        // and stored in DB 1
L     P#0.0        // set pointer to the 1. value of DB 1
T     MD    42    // store pointer in flag
AUF   DB    1    // open DB 1

// Check for new minimum:
loop: L     DBW [MD 42] // load input value from DB
L     MW    46    // load previous minimum value
>=I                    // is the input value exceeding
                        // the previous minimum?
SPB   max        // yes: check for maximum
TAK                    // no: exchange accu1 and accu2 -
                        // then the measuring value is in
                        // accu1 again
T     MW    46    // store new minimum in flag

```

continued ...

... continue

```

//Check for a new maximum:
max: L   DBW [MD   42] // load input value from DB
     L   MW   48     // load previous maximum
     <=I                                     // is the input value less the
                                           // previous maximum?
     SPB  ex         //   yes: next value
     TAK                                     //   no:  exchange accu1 and accu2 -
                                           //       then the measuring value is in
                                           //       in accu1 again
     T   MW   48     //       store new maximum in flag

ex:  NOP   0
     //Set pointer to the next value in DB 1:
     L   MD   42     // load pointer from flag
     L   P#2.0      // 2bytes because the input values were
                                           // stored as words in the DB 1
     +D                                     // increment pointer
     T   MD   42     // store pointer in flag

//Compare pointer with length of read data:
SRD   4
     L   MD   38     // number of read values
     <D                                     // Does the pointer point to a valid field
                                           // in the DB 1?
     SPB  loop      //   yes: check next value

```

Process

The recording at FIFO operation is started by setting flag 20.0. From this moment on the whole buffered input values of channel 0 were every 10ms cyclically read and stored in the data block.

The evaluation for minimum and maximum is executed in a loop. Here the number of read values and so the number of necessary loop operations is represented by the parameter *LEN*.

After evaluation of the whole read data the OB 35 is finished.

Variable table

The recording at FIFO operation is started by setting flag 20.0. The cyclic read access is indicated by flag 20.2.

The channel to be read may be defined by flag 21.

At a cyclic read access every 10ms and a sample time of 100µs about 100 values may be read from the buffer. The number of read values is reported in flag 38. The minimum respectively maximum value may be found in the flag word 46 respectively 48.

	Address	Display format	Status value	Modify value
1	// Start of FIFO function if flag is "true"			
2	M 20.0	BOOL	false	
3				
4	// Data are read if "true"			
5	M 20.2	BOOL	true	
6				
7	// Return value of start call			
8	MW 22	HEX	W#16#0000	
9				
10	// Channel to be read			
11	MB 21	DEC	0	
12				
13	// Return value while reading			
14	MW 32	HEX	W#16#0000	
15				
16	// Number of read values			
17	MD 38	DEC	L#100	
18				
19	// Determined minimum			
20	MW 46	DEC	-4802	
21				
22	// Determined maximum			
23	MW 48	DEC	12806	
24				
25	// Input values of the channels			
26	PEW 100	DEC	9731	
27	PEW 102	DEC	6	
28	PEW 104	DEC	6	
29	PEW 106	DEC	3	
30	PEW 108	DEC	7	
31	PEW 110	DEC	5	
32	PEW 112	DEC	5	
33	PEW 114	DEC	3	
34				
35				

Diagnostics

Overview

A diagnostic is an error message to a superordinated system (CPU). If enabled by parameterization the following events can release a diagnostic interrupt:

- Error in parameterization
- Process interrupt lost
- Measuring range over-/underflow
- External power supply is missing

At a diagnostic interrupt the CPU interrupts the user application and jumps to the OB 82. Within this OB you can accordingly react to the requested diagnostics information of the module.

In the case of an error diagnostic_{comming} and with correction diagnostic_{going} is released.

Error indication via measuring value and LEDs

The module sends the measuring value 7FFFh at overflow, when recognizing a parameterization error or power supply is missing and 8000h at underflow.

The group error LED (SF) indicates an error, if the diagnostics interrupt is activated.

Evaluating the diagnostics

At a diagnostics event the CPU interrupts the user program and jumps into the OB 82. This OB allows you via according programming to request detailed diagnostic information with record set 0 and 1 by means of the SFCs 51 and 59 and react to it.

After processing of the OB 82, the processing of the user application is continued. The diagnostic data are consistent until leaving the OB 82.

As soon as you have enabled the diagnostic interrupt, *record set 0* is transferred to the superordinated system in cause of an error. The *record set 0* has a fixed content and a length of 4byte. The content of *record set 0* may be monitored in plain text in the diagnosis window of the CPU.

For extended diagnostics during run time, you may also evaluate the *record set 1* of 16byte length via SFCs 51 and 59.

Record set 0 and 1 have the following structure:

**Diagnostics
record set 0***Record set 0 (Byte 0 to 3):*

Byte	Bit 7 ... Bit 0	Default
0	Bit 0: Error in module Bit 1: Internal error Bit 2: External error Bit 3: Channel error Bit 4: External power supply is missing Bit 6, 5: reserved Bit 7: Wrong parameters in module	00h
1	Bit 3 ... 0: Module class 0101 Analog module Bit 4: Channel information present Bit 7 ... 5: reserved	15h
2	reserved	00h
3	Bit 5 ... 0: reserved Bit 6: Process interrupt lost Bit 7: reserved	00h

**Diagnostics
record set 1***Byte 0 to 15:*

The record set 1 contains the 4byte of record set 0 and additionally 12byte module specific diagnostic data.

The diagnostic bytes have the following assignment:

Record set 1 (Byte 0 to 15):

Byte	Bit 7 ... Bit 0	Default
0 ... 3	Content record set 0 (see previous page)	-
4	Bit 6 ... 0: Channel type 70h: Digital input 71h: Analog input 72h: Digital output 73h: Analog output 74h: Analog in-/output Bit 7: More channel types present 0: no 1: yes	71h
5	Bit 7 ... 0: Number of diagnostic bits, that the module throws per channel	08h
6	Bit 7 ... 0: Number of similar channels of a module	08h
7	Bit 0: Channel error Channel 0 ... Bit 7: Channel error Channel 7	00h
8	Bit 0: Project engineering/Parameterization error Channel 0 Bit 5 ... 1: reserved Bit 6: Underflow Channel 0 Bit 7: Overflow Channel 0	00h
...	...	
15	Bit 0: Project engineering/Parameterization error Channel 7 Bit 5 ... 1: reserved Bit 6: Underflow Channel 7 Bit 7: Overflow Channel 7	00h

Process interrupts

When a process interrupt occurs, the CPU interrupts the user application and jumps to OB 40. Within the OB 40 there is the possibility to get the basic address of the module, which released the process interrupt by means of the local word 6.

At the operation mode oscilloscope-/FIFO the process interrupts are deactivated.

Activator

The following releases for a process interrupt may be defined during parameterization:


- Limit overflow
- Limit underflow
- End of cycle as soon as measuring value conversion of every channel has finished.

Interrupt data

The interrupt data of the module may be accessed by local double word 8. The local double word 8 has the following structure:

Local double word 8	Bit 7...0
Byte 0	Upper limit overflow Bit 0: Channel 0 ⋮ Bit 7: Channel 7
Byte 1	Lower limit underflow Bit 0: Channel 0 ⋮ Bit 7: Channel 7
Byte 2	Event end of cycle Bit 2...0: reserved Bit 3: End of cycle reached Bit 7...4: reserved
Byte 3	reserved

In the following illustration the interrupt behavior during limit exceedance is graphically represented:



- (1) Process interrupt limit exceedance
- (2) no reaction
- (3) Process interrupt limit exceedance
- (4) Diagnostic interrupt_{coming} overflow channel
- (5) Diagnostic interrupt_{going} overflow channel

331-7AF70 - AI 8x16Bit I


Order data AI 8x16Bit, ±20mA VIPA 331-7AF70

Description The analog input modules transform analog signals from the process into digital signals for the internal processing. The modules are preset to one measuring range.

- Properties**
- 8 inputs
 - Oscilloscope-/FIFO-Function parameterizable
 - The 8 inputs are read synchronous
 - Measuring value resolution 15Bit + sign
 - Suitable for sensors ±20mA
 - Parameterizable diagnostic and process interrupt
 - Isolated to the backplane bus and between the channels

Default settings After Power ON the diagnostics function of every channel is deactivated.


Structure



Pin assignment status monitor

Depending on the module current or voltage sensors may be connected.

Pin	Assignment	Connection	LED	Description
1	Power supply DC 24V	1 — L+	SF	LED (red) Group error, ON as soon as a diagnostic entry is present
2	+ Channel 0	2 —		
3	Ground Channel 0	3 —		
4	+ Channel 1	4 —		
5	Ground Channel 1	5 —		
6	+ Channel 2	6 —		
7	Ground Channel 2	7 —		
8	+ Channel 3	8 —		
9	Ground Channel 3	9 —		
10	n.c.	10 —		
11	n.c.	11 —		
12	+ Channel 4	12 —		
13	Ground Channel 4	13 —		
14	+ Channel 5	14 —		
15	Ground Channel 5	15 —		
16	+ Channel 6	16 —		
17	Ground Channel 6	17 —		
18	+ Channel 7	18 —		
19	Ground Channel 7	19 —		
20	Power supply Ground	20 — M		



Attention!

Please regard that the modules described here do not have hardware precautions against wrong wiring. The modules are fix preset to one measuring range.

For example, the modules may get a defect if you connect a voltage at current measuring module.

Technical Data

Order number	331-7AF70
Type	SM 331S - SPEED-Bus
SPEED-Bus	✓
Current consumption/power loss	
Current consumption from backplane bus	530 mA
Power loss	4 W
Technical data analog inputs	
Number of inputs	8
Cable length, shielded	-
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	62 mA
Voltage inputs	-
Min. input resistance (voltage range)	-
Input voltage ranges	-
Operational limit of voltage ranges	-
Basic error limit voltage ranges with SFU	-
Current inputs	✓
Min. input resistance (current range)	100 Ω
Input current ranges	-20 mA ... +20 mA
Operational limit of current ranges	+/-0.6%
Basic error limit current ranges with SFU	+/-0.4%
Resistance inputs	-
Resistance ranges	-
Operational limit of resistor ranges	-
Basic error limit	-
Resistance thermometer inputs	-
Resistance thermometer ranges	-
Operational limit of resistance thermometer ranges	-
Basic error limit thermoresistor ranges	-
Thermocouple inputs	-
Thermocouple ranges	-
Operational limit of thermocouple ranges	-
Basic error limit thermoelement ranges	-
Programmable temperature compensation	-
External temperature compensation	-
Internal temperature compensation	-
Resolution in bit	16
Measurement principle	successive approximation
Basic conversion time	25 μs all channels
Noise suppression for frequency	-
Initial data size	16 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	yes
Process alarm	yes, parameterizable
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	none
Group error display	red SF LED
Channel error display	none
Isolation	
Between channels	✓
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-

Order number	331-7AF70
Max. potential difference between inputs (Ucm)	DC 30 V
Max. potential difference between Mana and Mintern (Uiso)	-
Max. potential difference between inputs and Mana (Ucm)	-
Max. potential difference between inputs and Mintern (Uiso)	DC 75 V/ AC 60 V
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	16
Output bytes	0
Parameter bytes	41
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	-
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	235 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

Additional Technical Data

Order number	VIPA 331-7AF70
Suppression of interference, Limits of error	
Noise suppression for $f=nx$ ($f1\pm1\%$) ($f1$ = Interference frequency, $n=1,2,\dots$) - Common-mode interference ($U_{CM}<?V$)	($U_{CM}<20V$) >80dB
Crosstalk between the inputs	>50dB
Temperature error (reference to the input range)	$\pm 0.0025\%/K$
Linearity error (with reference to the input range)	$\pm 0.02\%$
Repeatability (in steady state at 25°C, reference to the input range)	$\pm 0.05\%$
Data for selecting a sensor	
Maximum input current for current input (destruction limit)	max. 40mA
Connection of the sensor - for measuring current 2-wire transmitter	possible

331-7BF70 - AI 8x16Bit U


Order data AI 8x16Bit, ±10V VIPA 331-7BF70

Description The analog input modules transform analog signals from the process into digital signals for the internal processing. The modules are preset to one measuring range.

- Properties**
- 8 inputs
 - Oscilloscope-/FIFO-Function parameterizable
 - The 8 inputs are read synchronous
 - Measuring value resolution 15Bit + sign
 - Suitable for sensors ±10V
 - Parameterizable diagnostic and process interrupt
 - Isolated to the backplane bus and between the channels

Default settings After Power ON the diagnostics function of every channel is deactivated.


Structure



Pin assignment status monitor

Depending on the module current or voltage sensors may be connected.

Pin	Assignment	Connection	LED	Description
1	Power supply DC 24V	1 — L+	SF	LED (red) Group error, ON as soon as a diagnostic entry is present
2	+ Channel 0	2 —		
3	Ground Channel 0	3 —		
4	+ Channel 1	4 —		
5	Ground Channel 1	5 —		
6	+ Channel 2	6 —		
7	Ground Channel 2	7 —		
8	+ Channel 3	8 —		
9	Ground Channel 3	9 —		
10	n.c.	10 —		
11	n.c.	11 —		
12	+ Channel 4	12 —		
13	Ground Channel 4	13 —		
14	+ Channel 5	14 —		
15	Ground Channel 5	15 —		
16	+ Channel 6	16 —		
17	Ground Channel 6	17 —		
18	+ Channel 7	18 —		
19	Ground Channel 7	19 —		
20	Power supply Ground	20 — M		



Attention!

Please regard that the modules described here do not have hardware precautions against wrong wiring. The modules are fix preset to one measuring range.

For example, the modules may get a defect if you connect a voltage at current measuring module.

Technical Data

Order number	331-7BF70
Type	SM 331S - SPEED-Bus
SPEED-Bus	✓
Current consumption/power loss	
Current consumption from backplane bus	530 mA
Power loss	4 W
Technical data analog inputs	
Number of inputs	8
Cable length, shielded	-
Rated load voltage	DC 24 V
Current consumption from load voltage L+ (without load)	62 mA
Voltage inputs	✓
Min. input resistance (voltage range)	120 kΩ
Input voltage ranges	-10 V ... +10 V
Operational limit of voltage ranges	+/-0.6%
Basic error limit voltage ranges with SFU	+/-0.4%
Current inputs	-
Min. input resistance (current range)	-
Input current ranges	-
Operational limit of current ranges	-
Basic error limit current ranges with SFU	-
Resistance inputs	-
Resistance ranges	-
Operational limit of resistor ranges	-
Basic error limit	-
Resistance thermometer inputs	-
Resistance thermometer ranges	-
Operational limit of resistance thermometer ranges	-
Basic error limit thermoresistor ranges	-
Thermocouple inputs	-
Thermocouple ranges	-
Operational limit of thermocouple ranges	-
Basic error limit thermoelement ranges	-
Programmable temperature compensation	-
External temperature compensation	-
Internal temperature compensation	-
Resolution in bit	16
Measurement principle	successive approximation
Basic conversion time	25 μs all channels
Noise suppression for frequency	-
Initial data size	16 Byte
Status information, alarms, diagnostics	
Status display	none
Interrupts	yes
Process alarm	yes, parameterizable
Diagnostic interrupt	yes, parameterizable
Diagnostic functions	yes
Diagnostics information read-out	possible
Supply voltage display	none
Group error display	red SF LED
Channel error display	none
Isolation	
Between channels	✓
Between channels of groups to	-
Between channels and backplane bus	✓
Between channels and power supply	✓
Max. potential difference between circuits	-

Order number	331-7BF70
Max. potential difference between inputs (U _{cm})	DC 30 V
Max. potential difference between Mana and Mintern (U _{iso})	-
Max. potential difference between inputs and Mana (U _{cm})	-
Max. potential difference between inputs and Mintern (U _{iso})	DC 75 V/ AC 60 V
Max. potential difference between Mintern and outputs	-
Insulation tested with	DC 500 V
Datasizes	
Input bytes	16
Output bytes	0
Parameter bytes	41
Diagnostic bytes	16
Housing	
Material	PPE
Mounting	-
Mechanical data	
Dimensions (WxHxD)	40 x 125 x 120 mm
Weight	235 g
Environmental conditions	
Operating temperature	0 °C to 60 °C
Storage temperature	-25 °C to 70 °C
Certifications	
UL508 certification	yes

Additional Technical Data

Order number	VIPA 331-7BF70
Suppression of interference, Limits of error	
Noise suppression for $f=nx$ ($f1\pm1\%$) ($f1$ = Interference frequency, $n=1,2,\dots$) - Common-mode interference ($U_{CM}<?V$)	($U_{CM}<20V$) >80dB
Crosstalk between the inputs	>50dB
Temperature error (reference to the input range)	$\pm 0.0025\%/K$
Linearity error (with reference to the input range)	$\pm 0.02\%$
Repeatability (in steady state at 25°C, reference to the input range)	$\pm 0.05\%$
Data for selecting a sensor	
Maximum input voltage for voltage input (destruction limit)	max. 30V
Connection of the sensor - for measuring voltage	possible

